

AMENDED FINAL LICENSE APPLICATION

Volume I of III
Exhibits A through D

Deleted: v

Byllesby-Buck Hydroelectric Project
(FERC No. 2514)

February 28, 2023

Deleted: 2

Prepared by:



Prepared for:

Appalachian Power Company



An **AEP** Company

BOUNDLESS ENERGY™

This page intentionally left blank.

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
 FERC PROJECT NO. 2514
 AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|-------------------|---|----------|
| Executive Summary | | |
| | Introduction..... | ES-1 |
| | Summary of Byllesby-Buck Hydroelectric Project | ES-2 |
| | Agency Consultation and Relicensing Process | ES-3 |
| | Summary of Proposed Action and Enhancement Measures..... | ES-8 |
| | Amended FLA Road Map..... | ES-11 |
| | Initial Statement (18 CFR §4.51(a))..... | IS-i |
| | Exhibit A - Project Description (18 CFR §4.51(b))..... | A-1 |
| A.1 | Project Overview and Location..... | A-1 |
| A.2 | Project Description..... | A-4 |
| A.3 | Existing Project Facilities..... | A-8 |
| A.3.1 | Reservoirs | A-8 |
| A.3.2 | Spillway and Dam | A-9 |
| A.3.3 | Low-Level Outlets and Sluice Gates..... | A-16 |
| A.3.4 | Forebay and Intake | A-16 |
| A.3.5 | Bypass Reach | A-17 |
| A.3.6 | Powerhouse | A-18 |
| A.4 | Existing and Proposed Turbines and Generators | A-19 |
| A.4.1 | Authorized Installed Capacity - Existing | A-19 |
| A.4.2 | Byllesby Development..... | A-19 |
| A.4.3 | Buck Development..... | A-23 |
| A.4.4 | Authorized Installed Capacity - Proposed..... | A-26 |
| A.5 | Transmission..... | A-28 |
| A.6 | Lands of the United States | A-30 |
| | Exhibit B - Project Operation and Resource Utilization (18 CFR §4.51(c))..... | B-1 |
| B.1 | Description of Plant Operations..... | B-1 |
| B.1.1 | Drainage Basin Description | B-1 |
| B.1.2 | Project Operation | B-1 |

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
 FERC PROJECT NO. 2514
 AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|----------------|--|-----------------|
| B.1.3 | Flood Operations..... | B-3 |
| B.1.4 | Plant Factor..... | B-7 |
| B.2 | Estimated Energy Production and Dependable Capacity of the Project..... | B-8 |
| B.2.1 | Generation..... | B-8 |
| B.2.2 | Dependable Generating Capacity..... | B-10 |
| B.2.3 | Flows..... | B-10 |
| B.2.4 | Reservoir Storage Capacity..... | B-11 |
| B.2.5 | Hydraulic Capacity..... | B-13 |
| B.2.6 | Tailwater Rating Curve..... | B-14 |
| B.2.7 | Head vs. Capability..... | B-18 |
| B.3 | Power Utilization..... | B-20 |
| B.4 | Future Development..... | B-20 |
| B.5 | Flow Figures..... | B-21 |
| Exhibit C | - Construction History and Proposed Construction Schedule (18 CFR §4.51(d))..... | C-1 |
| C.1 | Construction of Existing Facilities..... | C-1 |
| C.1.1 | Byllesby Development..... | C-1 |
| C.1.2 | Buck Development..... | C-3 |
| C.2 | Construction of Proposed Facilities..... | C-5 |
| Exhibit D | - Costs and Financing (18 CFR §4.51(e))..... | D-1 |
| D.1 | Original Cost of Project..... | D-1 |
| D.2 | Project Takeover Cost Pursuant to Section 14 of the FPA..... | D-1 |
| D.2.1 | Fair Market Value..... | D-1 |
| D.2.2 | Net Investment..... | D-2 |
| D.2.3 | Severance Damages..... | D-2 |
| D.3 | Estimated Costs of New Development..... | D-4 |
| D.3.1 | Land and Water Rights..... | D-4 |
| D.3.2 | Cost of New Facilities..... | D-4 |
| D.4 | Estimated Average Annual Cost of Project..... | D-4 |
| D.4.1 | Current Annual Costs..... | D-4 |

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
FERC PROJECT NO. 2514
AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|----------------|---|-----------------|
| D.4.2 | Annual Value of Project Power | D-7 |
| D.5 | Sources and Extent of Financial and Annual Revenues..... | D-7 |
| D.6 | Cost to Develop the License Application..... | D-7 |
| D.7 | On-Peak and Off-Peak Values of the Project..... | D-8 |
| D.8 | Estimated Average Increase or Decrease in Generation..... | D-8 |
| D.9 | PURPA Benefits | D-8 |

List of Tables

| | |
|--|-------|
| Table ES-1. Resolution of Comments on Byllesby-Buck Hydroelectric Project Draft License Application (<i>Previously Filed with FLA</i>) | ES-7 |
| Table ES-2. Resolution of Comments on Byllesby-Buck Hydroelectric Project Updated Study Report (<i>Previously Filed with FLA</i>) | ES-7 |
| Table ES-3. License Application Road Map | ES-13 |
| Table A.3-1. Byllesby Development Reservoir Data | A-8 |
| Table A.3-2. Buck Development Impoundment Data | A-9 |
| Table A.4-1. Byllesby Development Turbine and Generator Data - Existing..... | A-20 |
| Table A.4-2. Byllesby Development Turbine and Generator Data – Proposed (Upgrades to Units 1, 3 and 4) | A-22 |
| Table A.4-3. Buck Development Turbine and Generator Data - Existing | A-24 |
| Table A.4-4. Buck Development Turbine and Generator Data – Proposed (Upgrades to Units 1 and 3) | A-26 |
| Table A.5-1. Appurtenant Mechanical, Electrical, and Transmission Equipment – Byllesby Development..... | A-29 |
| Table A.5-2. Appurtenant Mechanical, Electrical, and Transmission Equipment – Buck Development | A-29 |
| Table B.1-1. Exceedance Probability of Discharge to the Bypass Reaches at Byllesby and Buck Dams..... | B-3 |
| Table B.2-1. Byllesby Monthly and Annual Generation (MWh) (2016-2020)..... | B-8 |
| Table B.2-2. Buck Monthly and Annual Generation (MWh) (2016-2020) | B-9 |
| Table B.2-3. Monthly and Annual Average Project Outflows (cfs) (2016-2020) | B-9 |
| Table B.2-4 New River Flow Data (USGS Ivanhoe Gage), 1996 through 2020 | B-11 |

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
FERC PROJECT NO. 2514
AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|----------------|--|-----------------|
| Table D.2-1. | Byllesby-Buck Project Net Book Value..... | D-2 |
| Table D.4-1. | Preliminary Cost Estimate of Resource PM&E Measures Proposed by Appalachian at the Byllesby-Buck Project | D-6 |

List of Figures

| | | |
|----------------|--|------|
| Figure A.3-1. | Byllesby Dam Spillway Gates (Existing)..... | A-11 |
| Figure A.3-2. | Byllesby Dam Spillway Gates (Proposed) | A-12 |
| Figure A.3-3. | Buck Dam Spillway Gates (Existing) | A-14 |
| Figure A.3-4. | Buck Dam Spillway Gates (Proposed) | A-15 |
| Figure B.1-1. | Byllesby Spillway Capacity Curve..... | B-5 |
| Figure B.1-2. | Buck Spillway Capacity Curve | B-7 |
| Figure B.2-1. | Byllesby Development Reservoir Storage Capacity Curve | B-12 |
| Figure B.2-2. | Buck Development Reservoir Storage Capacity Curve..... | B-13 |
| Figure B.2-3. | Byllesby Development Tailwater Curve | B-15 |
| Figure B.2-4. | Byllesby Development Extended Tailwater Curve | B-16 |
| Figure B.2-5. | Buck Development Tailwater Curve | B-17 |
| Figure B.2-6. | Buck Development Extended Tailwater Curve | B-18 |
| Figure B.2-7. | Byllesby Development Head vs. Power Plant Capability | B-19 |
| Figure B.2-8. | Byllesby Development Head vs. Power Plant Capability | B-20 |
| Figure B.5-1. | Byllesby Development: Flow Through One Unit (Existing Units) | B-22 |
| Figure B.5-2. | Buck Development: Flow Through One Unit (Existing Units)..... | B-23 |
| Figure B.5-7. | Byllesby Development: Flow Over Vertical Drop (Sluice) Gate | B-28 |
| Figure B.5-8. | Buck Development: Flow Through Vertical Lift (Sluice) Gate | B-29 |
| Figure B.5-9. | Byllesby Development Daily Average Inflow | B-30 |
| Figure B.5-10. | Byllesby Development Monthly Average Inflow | B-31 |
| Figure B.5-11. | Buck Development Daily Average Inflow..... | B-32 |
| Figure B.5-12. | Buck Development Daily Average Inflow..... | B-33 |
| Figure B.5-13. | Byllesby Development Monthly Flow Duration Curves..... | B-34 |
| Figure B.5-14. | Byllesby Annual Rating Curve | B-35 |

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
 FERC PROJECT NO. 2514
 AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|----------------|--|-----------------|
| Figure B.5-15. | Byllesby Development January Flow Duration Curve | B-36 |
| Figure B.5-16. | Byllesby Development February Flow Duration Curve | B-36 |
| Figure B.5-17. | Byllesby Development March Flow Duration Curve | B-37 |
| Figure B.5-18. | Byllesby Development April Flow Duration Curve..... | B-37 |
| Figure B.5-19. | Byllesby Development May Flow Duration Curve | B-38 |
| Figure B.5-20. | Byllesby Development June Flow Duration Curve | B-38 |
| Figure B.5-21. | Byllesby Development July Flow Duration Curve..... | B-39 |
| Figure B.5-22. | Byllesby Development August Flow Duration Curve..... | B-39 |
| Figure B.5-23. | Byllesby Development September Flow Duration Curve | B-40 |
| Figure B.5-24. | Byllesby Development October Flow Duration Curve | B-40 |
| Figure B.5-25. | Byllesby Development November Flow Duration Curve | B-41 |
| Figure B.5-26. | Byllesby Development December Flow Duration Curve | B-41 |
| Figure B.5-27. | Buck Development Monthly Flow Duration Curves | B-42 |
| Figure B.5-28. | Buck Development Annual Rating Curve | B-43 |
| Figure B.5-29. | Buck Development January Flow Duration Curve..... | B-44 |
| Figure B.5-30. | Buck Development February Flow Duration Curve | B-44 |
| Figure B.5-31. | Buck Development March Flow Duration Curve | B-45 |
| Figure B.5-32. | Buck Development April Flow Duration Curve | B-45 |
| Figure B.5-33. | Buck Development May Flow Duration Curve..... | B-46 |
| Figure B.5-34. | Buck Development June Flow Duration Curve..... | B-46 |
| Figure B.5-35. | Buck Development July Flow Duration Curve | B-47 |
| Figure B.5-36. | Buck Development August Flow Duration Curve | B-47 |
| Figure B.5-37. | Buck Development September Flow Duration Curve..... | B-48 |
| Figure B.5-38. | Buck Development October Flow Rating Curve..... | B-48 |
| Figure B.5-39. | Buck Development November Flow Duration Curve..... | B-49 |
| Figure B.5-40. | Buck Development December Flow Duration Curve..... | B-49 |

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
FERC PROJECT NO. 2514
AMENDED FINAL LICENSE APPLICATION**

TABLE OF CONTENTS

| Section | Title | Page No. |
|----------------|--------------|-----------------|
|----------------|--------------|-----------------|

Appendices

| | | |
|--|--|--|
| | <u>Appendix A – Byllesby-Buck Supplemental Flow Exceedance Plots (Exhibit B) – Previously Filed with FLA</u> | |
|--|--|--|



Acronyms and Abbreviations

| | |
|-------------------------|---|
| °C | degrees Celsius |
| °F | degrees Fahrenheit |
| AEP | American Electric Power |
| AIR | Additional Information Request |
| Appalachian or Licensee | Appalachian Power Company |
| Buck | Buck Development |
| Byllesby | Byllesby Development |
| CFR | Code of Federal Regulations |
| cfs | cubic feet per second |
| COC | Columbus Operations Center |
| CWA | Clean Water Act |
| CEII | Critical Energy/Electric Infrastructure Information |
| CUI/PRIV | Controlled Unclassified Information/Privileged |
| dbh | diameter at breast height |
| DLA | Draft License Application |
| EAP | Emergency Action Plan |
| EL. | elevation |
| FERC or Commission | Federal Energy Regulatory Commission |
| FLA | Final License Application |
| ft | feet/foot |
| FPA | Federal Power Act |
| GSU | generator step-up transformer |
| hp | horsepower |
| HPU | hydraulic power unit |
| Hz | hertz |
| ILP | Integrated Licensing Process |
| kV | kilovolt |
| kW | kilowatt |
| MEP | most efficient point |
| MW | megawatt |
| MWh | megawatt hour |
| NGVD | Nation Geodetic Vertical Datum of 1929 |
| PH | phase |
| POR | period of record |



| | |
|----------------------|---|
| Project | Byllesby-Buck Hydroelectric Project |
| PM&E | protection, mitigation, and enhancement |
| rpm | rotations per minute |
| RSP | Revised Study Plan |
| SD | Scoping Document |
| USGS | U.S. Geological Survey |
| USACE | U.S. Army Corps of Engineers |
| USC | United States Code |
| V | volt |
| VAC | Virginia Administrative Code |
| VDCR | Virginia Department of Conservation and Recreation |
| VDWR | Virginia Department of Wildlife Resources |
| VDEQ | Virginia Department of Environmental Quality |
| VWP | Virginia Water Protection |

AMENDED FINAL LICENSE APPLICATION
BYLLESBY-BUCK HYDROELECTRIC PROJECT
(FERC No. 2514)

EXECUTIVE SUMMARY

This page intentionally left blank.



Executive Summary

Introduction

Appalachian Power Company (Appalachian or Licensee), a unit of American Electric Power (AEP), is the Licensee, owner, and operator of the two-development Byllesby-Buck Hydroelectric Project (Project) (Federal Energy Regulatory Commission [FERC or Commission] Project No. 2514), located on the upper New River in Carroll County, Virginia.

The Project is currently licensed by FERC under the authority granted to FERC by Congress through the Federal Power Act, 16 United States Code (USC) §791(a), et seq., to license and oversee the operation of non-federal hydroelectric projects on jurisdictional waters and/or federal land. The transmission corridor crosses 7.23 acres of federal lands (Jefferson National Forest). Appalachian understands these lands to be held in easement as the corridor pre-dates the Jefferson National Forest.

The Project underwent relicensing in the early 1990s, including conversion to run-of-river operations and incorporating additional protection, mitigation, and enhancement (PM&E) measures. The current operating license for the Project expires on February 29, 2024. Accordingly, Appalachian is pursuing a new license for the Project pursuant to the Commission's Integrated Licensing Process (ILP), as described at 18 Code of Federal Regulations (CFR) Part 5. In accordance with FERC's regulations at 18 CFR §16.9(b), Appalachian filed its Final License Application (FLA) with FERC on February 28, 2022, for a 50-year license for the Project. Appalachian believes that the level of investment in terms of plant modernization and environmental measures proposed in the FLA (and this amended FLA) will support this requested license term.

Appalachian filed additional information with the Commission after the filing of the FLA as follows:

- Appalachian filed the Revised Aquatic Resources and Bypass Reach Flow and Aquatic Habitat Study Reports as supplemental information 45 days after filing the FLA (April 14, 2022), which allowed the Licensee additional time to conduct more in-depth study analyses to address FERC and agency comments on the Draft License Application and Updated Study Report.
- Appalachian filed responses to two sets of Additional Information Requests (AIRs) issued by FERC. Appalachian's responses were filed on September 8, 2022, and January 30, 2023. The AIR responses provided additional information to support FERC's analyses of, and

Deleted: must file

Deleted: no later than

Deleted: . Appalachian is applying

Deleted: Appalachian filed the Revised Aquatic Resources and Bypass Reach Flow and Aquatic Habitat Study Reports as supplemental information 45 days after filing the FLA (April 14, 2022), which allowed the Licensee additional time to conduct additional study analyses to address FERC and agency comments on the Draft License Application and Updated Study Report. ...



[provided minor modifications to Appalachian's relicensing proposals. Where relevant information from these AIR responses has been incorporated into this amended FLA.](#)

[After the filing of the FLA, Appalachian received additional informal comments and conducted informal consultation with agencies related to bypass reach minimum flows at the Project. To address these requests, as well as previously expressed interests by agencies and FERC staff in reducing the frequency of reservoir drawdowns for flashboard repair or reinstallation, Appalachian is proposing to replace several wooden flashboard sections at the Byllesby and Buck developments with inflatable Obermeyer gates. Appalachian is also proposing to operate Obermeyer gates to provide a continuous bypass reach minimum flow of approximately 35 cubic feet per second \(cfs\) at the Byllesby Development and a seasonal \(February 15 – May 15\) continuous bypass reach minimum flow of approximately 100 cfs at the Buck Development. Appalachian is now filing this amended FLA to formally propose these and other additional protection, mitigation, and enhancement \(PM&E\) measures as revisions to Appalachian's relicensing proposal.](#)

[Appalachian has updated several of its application exhibits to reflect proposed changes, additional PM&E measures, information submitted to FERC in response to AIRs, and errors identified during the revision process. A revised Application Road Map is provided below. For the convenience of the Commission and relicensing participants, new language in this Amended FLA is included in tracked changes and clarifying footnotes have been added. Application exhibits not affected by the proposed changes have not been refiled and are incorporated by reference.](#)

Summary of Byllesby-Buck Hydroelectric Project

The Project consists of two hydroelectric developments. The Byllesby Development (Byllesby) is located about nine miles north of the city of Galax, Virginia, on the New River. The Buck Development (Buck) is located about 3 miles downstream from the Byllesby dam. Each development consists of a reservoir, concrete gravity dam and spillway, and powerhouse, and the Project also includes a control house and switchyard located at the Byllesby Development and two 2-mile long 13.2-kV overhead transmission lines connecting the two developments. The Project has been operated by Appalachian over the previous license term in a run-of-river mode, utilizing upper New River inflows to provide up to 30.1 megawatts (MW) of renewable capacity and average annual energy generation of 92,891 megawatt hours (MWh).



Agency Consultation and Relicensing Process

Appalachian followed FERC's ILP in support of preparing this application for new license. Appalachian filed a Pre-Application Document (PAD) and associated Notice of Intent (NOI) with the Commission on January 7, 2019, to initiate the ILP. The PAD provided a description of the Projects and summarized existing, relevant, and reasonably available information to assist resource agencies, federally recognized Indian tribes, non-governmental organizations (NGOs) and other interested parties (collectively, "stakeholders") in identifying issues, determining information needs, preparing study requests, and analyzing the license application.

The Commission issued Scoping Document 1 (SD1) for the Project on March 8, 2019. As provided in 18 CFR §5.8(a) and §5.18(b), the Commission issued a notice of commencement of the relicensing proceeding concomitant with SD1. On April 10 and 11, 2019, the Commission held public scoping meetings and a site visit pursuant to 18 CFR §5.8(d). During these meetings, FERC staff presented information regarding the ILP and details regarding the study scoping process and how to request a relicensing study, including the Commission's study criteria. In addition, FERC staff solicited comments regarding the scope of issues and analyses for the Environmental Assessment. Resource agencies, Indian Tribes, NGOs, and other interested parties were afforded a 60-day period to request studies and provide comments on the PAD and SD1.

In accordance with ILP regulations, comments on the PAD and SD1 and study requests were due to FERC by May 7, 2019. Stakeholders filed letters with the Commission providing general comments, comments regarding the PAD and SD1, and/or study requests. Twenty-two formal study requests and/or comments were received during the comment period from the following stakeholders:

- Cherokee Nation
- Delaware Nation
- National Park Service
- New River Conservancy
- U.S. Fish and Wildlife Service (USFWS)
- Virginia Department of Conservation and Recreation (VDCR), Division of Planning and Recreation Resources and Division of Natural Heritage
- Virginia Department of Environmental Quality (VDEQ)
- Virginia Department of Wildlife Resources (VDWR) (formerly the Virginia Department of Game and Inland Fisheries)
- Virginia Department of Health (VDH)

Deleted: ;

Deleted: [VDGIF]



- Virginia Polytechnic Institute and State University (Virginia Tech)

FERC issued Scoping Document 2 (SD2) on June 21, 2019, and, in accordance with 18 CFR §5.11, Appalachian developed a Proposed Study Plan (PSP) for the Project that was filed with the Commission and made available to stakeholders on June 21, 2019. The PSP described Appalachian's proposed approaches for conducting studies and addressed agency and stakeholder study requests. Pursuant to 18 CFR §5.11(e), Appalachian held a PSP Meeting on July 18, 2019, for the purpose of clarifying the PSP, explaining initial information gathering needs, and addressing outstanding issues associated with the PSP. Appalachian received timely formal comments on the PSP from Commission staff, the USFWS, and [VDWR](#). Virginia Tech's College of Natural Resources and Environment filed multiple study requests on March 15, 2019.

Deleted: GIF

In accordance with 18 CFR §5.11, Appalachian developed a Revised Study Plan (RSP) for the Project, which incorporated comments and study requests considered in developing the PSP, the Commission's June 21, 2019 SD2 and comments on the PSP, and it was filed with the Commission and made available to stakeholders on October 18, 2019. On November 18, 2019 FERC issued the Study Plan Determination (SPD). On December 18, 2019, Appalachian filed a request for rehearing of the SPD. The SPD was subsequently modified by FERC by an Order on Rehearing dated February 20, 2020. The modified SPD required eight studies to be performed in support of issuing a new license for the Project, as listed below:

1. Bypass Reach Flow and Aquatic Habitat Study
2. Water Quality Study
3. Aquatic Resources Study
4. Wetlands, Riparian, and Littoral Habitat Characterization Study
5. Terrestrial Resources Study
6. Shoreline Stability Assessment Study
7. Recreation Study
8. Cultural Resources Study

On July 27, 2020, Appalachian filed an updated ILP study schedule and a request for extension of time to file the Initial Study Report (ISR) to account for Project delays resulting from the COVID-19 pandemic. The request was approved by FERC on August 10, 2020, and the filing deadline for the ISR for the Project was extended from November 17, 2020 to January 18, 2021.

On December 23, 2020, FERC issued Scoping Document 3 (SD3) for the Project, to account for updates about Commission's staff intent to conduct their National Environmental Policy Act (NEPA)

review in accordance with the Council on Environmental Quality's (CEQ) updated NEPA regulations at 40 CFR Part 1500-1518.

Appalachian filed the ISR on January 18, 2021, conducted a virtual ISR Meeting on January 28, 2021, and filed the ISR Meeting summary with the Commission on February 12, 2021. Written comments in response to Appalachian's filing of the ISR meeting summary were filed by USFWS, VDWR, and FERC staff. Appalachian filed a response to comments on the ISR on April 13, 2021. Because no substantive study modifications were requested in response to the ISR, FERC did not in turn provide a Determination on Requests for Study Modifications.

Throughout the study phase of the ILP (i.e., July 2020 through the USR), either by separate filing or in conjunction with the filings described above, Appalachian has provided FERC and relicensing participants with quarterly ILP study progress reports describing study activities completed by Appalachian, updates to the study schedule, and variances from the schedule or methods of the RSP.

In addition to the formal consultation activities describe above and as represented in Appendix I of Volume II of the [FLA](#), Appalachian conducted consultation with specific stakeholders in support of the Cultural Resources Study, informal consultation with stakeholders in association with study activities, and also convened and participated in additional meetings with relicensing participants throughout the pre-filing consultation period, including:

Deleted: is

- June 29, 2020: ILP Study Schedule Update to Agencies (Virtual Meeting) (VDWR, VDEQ, USFWS)
- August 28, 2020: Discussion of Bylesby-Buck Bypass Flow and Bypass Reach Study flow test scenarios (Virtual Meeting) (VDWR, USFWS, and VDEQ)
- October 23, 2020: Recreation Study Update (Virtual Meeting) (VDWR, VDCR-New River Trail State Park, USFWS, Carroll County, New River Conservancy)
- October 28, 2020: Bylesby-Buck Recreation Site Stakeholder Visit (VDWR, Carroll County, Land Planning Design Associates [LPDA], VDCR-New River Trail State Park)
- March 24, 2021: Recreation Stakeholder Meeting and Site Visit to Loafer's Rest recreational facility (VDWR)
- June 29, 2021: Potential Recreation Improvements Discussion with DWR (Virtual Meeting)

On October 1, 2021, Appalachian filed the Draft License Application (DLA) with the Commission and distributed notice of these filings to the Projects' mailing list. Comments on the DLA were filed by FERC staff (December 20, 2021), VDWR (December 22, 2021), and USFWS (December 30, 2021).

Studies were completed in 2021 and the USR was filed with the FERC on November 17, 2021. The USR meeting was held on December 1, 2021 and the meeting summary was filed on December 16, 2021. The following parties provided written comments in response to Appalachian's filing of the USR meeting summary: FERC staff (January 18, 2022), USFWS (January 18, 2022), and VDWR (January 18, 2022). On February 14, 2022, Appalachian filed with FERC a response to comments on the USR and a request for extension of time to file revised study reports (Bypass Reach Flow and Aquatic Habitat Study Report and Aquatic Resources Study Report), given the additional time and effort needed to address comments received on the USR. FERC filed a letter on February 17, 2022, requesting Appalachian include the proposed schedule with the FLA. Appalachian filed the revised study reports (Bypass Reach Flow and Aquatic Habitat Study Report and Aquatic Resources Study Report) on April 14, 2022.

Additional consultation conducted by Appalachian in support of preparation of the FLA included the following:

- January 26, 2022 distribution of the draft Recreation Management Plan to recreation stakeholders (VDWR, USFWS, VDCR, VDEQ, Carroll County, Town of Wytheville, and New River Conservancy) for a 30-day review period.
- Informal email and telephone communications (January-February 2022) with VDWR regarding fishery (walleye body depth) data and documentation of past stranding incidents in the Buck bypass reach, as well as the potential for occurrence of Eastern hellbender in each bypass reach.
- Virtual (WebEx) meetings with representatives from VDWR, USFWS, and VDEQ on February 1, 2022 and February 16, 2022 to discuss comments received in response to the USR and DLA.

Appalachian reviewed and considered comments received on both the DLA and USR as evidenced through further development of the Licensee's measures proposed in the FLA and summarized in Table ES-1 and Table ES-2¹ of the FLA.

¹ Table ES-1 (Resolution of Comments on Byllesby-Buck Hydroelectric Project Draft License Application) and Table ES-2 (Resolution of Comments on Byllesby-Buck Hydroelectric Project Updated Study Report) have been removed

Deleted: will

Deleted: or before

Deleted: is

Deleted: has

Deleted: is



Table ES-1. Resolution of Comments on Byllesby-Buck Hydroelectric Project Draft License Application ([Previously Filed with FLA](#)).

Table ES-2. Resolution of Comments on Byllesby-Buck Hydroelectric Project Updated Study Report ([Previously Filed with FLA](#)).

[Additional information provided and consultation conducted by Appalachian in support of preparation of the amended FLA include the following:](#)

- [Final License Application AIRs issued by FERC June 10, 2022 related to Exhibits D, E, and F of the FLA. The Applicant filed the Response to Final License Application AIRs September 8, 2022.](#)
- [Virtual meeting with representatives from USFWS, VDWR, VDEQ, and Appalachian on August 22, 2022, to discuss agencies' interests in and questions related to the feasibility of providing bypass reach minimum flows at the Project.](#)
- [Final License Application AIRs issued by FERC November 30, 2022 related to Exhibits A and E of the FLA. The Applicant filed the Response to Final License Application AIRs January 30, 2023.](#)
- [Letter filed with FERC and distributed to Project stakeholders on October 7, 2022, providing status update of Appalachian's ongoing evaluations and stakeholder consultation related to replacement of several flashboard bays with Obermeyer crest gates at the Project, and Appalachian's plan and schedule to file an amended FLA.](#)
- [Virtual meeting with representatives from USFWS, VDWR, VDEQ, and Appalachian on February 3, 2023, to share information about additional evaluations conducted by Appalachian in late 2022 and the bypass reach minimum flows to be proposed by Appalachian in the Amended FLA.](#)

[Copies of this correspondence, and additional consultation and correspondence since the filing of the FLA are provided in Appendix I-2, Volume II of this amended FLA.](#)

[from this Amended FLA and can be found in Appalachian \(2022\) or <https://elibrary.ferc.gov/eLibrary/search>, Docket Number P-2514, Accession Number 20220228-5319.](#)



Summary of Proposed Action and Enhancement Measures

The Project operates in a run-of-river mode under all flow conditions and Appalachian proposes to continue operating the Project as presently licensed. Under normal operating conditions, Appalachian operates the Project to use available flows for powerhouse generation, maintaining the elevation (EL.) of the Byllesby reservoir between EL. 2,078.2 feet (ft) and 2,079.2 ft and the Buck reservoir between EL. 2,002.4 ft and 2,003.4 ft. Appalachian is also presently required to release a minimum flow of approximately 360 cubic feet per second (cfs) or inflow to the Project, whichever is less, downstream of the Project powerhouses. Appalachian also proposes to continue funding of the USGS New River at Galax and Ivanhoe gages through the new license term.

During the new license term, Appalachian proposes to modernize the Byllesby and Buck developments to include replacement of Byllesby Units 1, ~~3~~ and 4 and Buck Units 1 and 3. All but one (Buck Unit 2) of the seven turbine-generator units installed at the Project are the original major components of the Project as constructed in 1912. Many of the major electrical and mechanical and supporting systems and components of the Project developments are nearing the end of their useful service life, when compared to industry-recognized standards. The existing vertical Francis units would be replaced by fixed blade Kaplan units. Unit upgrade activities would be confined to within the powerhouse, and there would be minimal changes to operating parameters for the Project. Following completion of the upgrades, the authorized installed capacities for the Byllesby and Buck developments will be 20,389.5 kW and 9,435 kW, respectively, with maximum hydraulic capacities of ~~5,511~~ cfs and ~~3,570~~ cfs, respectively.² Due to efficiencies of the Kaplan units and modern components, the upgrades are expected to increase average annual generation at the Project by approximately 25,927 MWh.

Deleted: 2

Deleted: 5,868

Deleted: 540

Appalachian also proposes to implement the following additional enhancement measures under the new license term:

- At the Byllesby Development, for the protection of aquatic resources, provide a continuous bypass reach minimum flow of approximately 35 cfs from any one or combination of the Obermeyer gates installed on the main spillway.
- At the Buck Development, for the protection of Walleye during spawning season, from February 15th – May 15th annually, provide a continuous bypass reach minimum flow of

² Corrected values provided in Appalachian's *Final License Application Errata* filed with FERC on March 25, 2022.



approximately 100 cfs from Obermeyer gates in Bays 25 and/or 26, located near the left abutment of the spillway. The start date for this seasonal bypass reach minimum flow release is conditioned on installation and commissioning of new Obermeyer gates.

- Spillway discharge ramping rate for the Buck Development bypass reach:
 - Prior to installation and commissioning of new Obermeyer gates in Bays 25 and 26, continue to implement the existing ramping rate for the Buck bypass reach with minor modification as described in this amended FLA whereby, following periods of spill when a spillway gate has been opened 2 ft or more, water will be released into the bypass reach through a 2-ft-gate opening for at least 2 hours, then the gate opening will be reduced to 0.5 ft for 3 hours before closing the gate.
 - Within 60 days following commissioning of new Obermeyer gates in Bays 25 and 26, file a modified ramping procedure for spillway gate (i.e., Obermeyer gate and Tainter gate) operations at the Buck Development with FERC for approval. The procedure will include measures to reduce the risk for stranding of fish, as feasible, under a range of typical operating and inflow scenarios and will be developed by Appalachian in consultation with the USFWS, VDWR, and VDEQ.
- Within 180 days of license issuance, file an updated Operation Compliance Monitoring Plan with FERC for approval. The plan will be developed by Appalachian in consultation with USFWS, VDWR, and VDEQ and will include the following:
 - Provisions for monitoring compliance with the operational requirements of the new license;
 - A description of gages or recording devices used to monitor operation compliance;
 - Processes for reporting deviations during normal operations, during emergencies, and for planned variances for Project maintenance or other purposes; and
 - An implementation schedule.
- Conduct Project maintenance and new license implementation activities, as applicable, in accordance with the USFWS's prevailing eagle management guidance and regulations.
- Implement the following measures for the protection of listed bat species at the Project during the new License term. It is not the intent of these measures to hold the Licensee to a higher standard than the applicable law or guidance for the bat species. Accordingly, these

Deleted: <#>the Project and file it with FERC for approval. The plan will be developed will include Continue to operate the Project in a run-of-river mode, maintaining the Byllesby reservoir between EL. 2,078.2 ft and 2,079.2 ft and the Buck reservoir between EL. 2,002.4 ft and 2,003.4 ft. Continue funding of the USGS New River at Galax and Ivanhoe gages.¶ <#>Continue to provide a minimum flow of 360 cfs, or inflow through the Project, whichever is less, to the New River downstream of each powerhouse.¶ <#>Implement a modified ramping rate for spillway gate operations at the Buck development; whereby, following periods of spill when a spillway gate has been opened 2 ft or more, water will continue to be released into the bypass reach through a 2-ft-gate opening for at least 2 hours, then the gate opening will be reduced to 1.0 ft for 2 hours and then to 0.5 ft for 2 hours before closing. approximately approximately left abutment; A ds;s, during ies.; and, Development of aAn ¶ <#>Develop and implement a Bypass Reach Aquatic Resources Protection Plan³ in consultation with USFWS and VDWR and for FERC approval. The Bypass Reach Aquatic Resources Protection Plan will include provisions for the spillway gate and ramping rate procedures, measures to identify and address (through visual inspection and relocation, if appropriate) isolated incidents of fish stranding in isolated pools along the left descending bank in the Buck bypass reach, and measures to reduce impacts of scheduled powerhouse outages. ¶



measures shall be subject to change in order to be consistent with changes in applicable law or vegetation clearing guidelines to be modified consistent with applicable regulations and industry best practices.

- The Licensee may remove hazard trees that the Licensee has a reasonable basis to believe pose a material threat to human life or property at any time, including to restore infrastructure after a weather event, without prior consultation with the Virginia DWR and the USFWS. The Licensee will subsequently inform the Virginia DWR and the USFWS of the activity and event.
- The Licensee may remove and trim trees during the period October 1 through March 31 without prior consultation with, or notification to, the Virginia DWR and USFWS.
- The Licensee may remove trees <3 inches diameter at breast height (dbh) at any time without prior consultation with, or notification to, the Virginia DWR and the USFWS.
- With the exception of hazard trees, should the Licensee find it necessary to remove or be required by FERC to remove suitable roost trees ≥ 3 inches dbh between April 1st and September 30th, the Licensee will consult with the USFWS and VDWR and not commence the tree clearing until such consultation is complete. The Licensee acknowledges that if the tree(s) to be removed are suitable roost trees or known habitat, further survey or assessment prior to tree removal may be required.
- Within 90 days following license issuance, file the Final Recreation Management Plan (RMP) with FERC for approval. The RMP will be developed by Appalachian in consultation with Project stakeholders, including provisions and schedule for improvements to existing Project facilities (Byllesby Boat Launch, Byllesby Dam Fishing Access, Byllesby Canoe Portage (Take-Out), New River Canoe Launch (Put-In), and Buck Canoe Portage [Take-Out and Put-In]) as well as construction of the Non-Project Loafer's Rest Area and Fishing Trail. In the event the RMP is submitted to FERC in time for processing as part of Appalachian's amended FLA, the Final RMP may be approved by the new license.



- [Within 120 days following license issuance, file the Historic Properties Management Plan \(HPMP\) with FERC for approval. The HPMP is being developed in consultation with consulting parties \(Tribes and State Historic Preservation Officer \[SHPO\]\).⁴](#)

Deleted: Finalize and implement the Recreation Management Plan in consultation with Project stakeholders, including provisions for improvements to existing Project facilities (Bylesby Boat Launch, Bylesby Dam Fishing Access, Bylesby Canoe Portage (Take-Out), New River Canoe Launch (Put-In), and Buck Canoe Portage [(Take-Out and Put-In)] as well as construction of the Non-Project Loafer's Rest Area and Fishing Trail. ¶

Amended FLA Road Map

The amended FLA is composed of three volumes⁵, two of which contain public information and one that contains Critical Energy/Infrastructure Information (CEII). The updated volumes and exhibits in this amended FLA are listed below. These revised documents replace those filed with the FLA.

Deleted: Finalize in consultation with consulting parties (Tribes, SHPO, and FERC) the draft Historic Properties Management Plan.

Deleted: Application

Deleted: Appalachian considers to

Volume I of III

- **Table of Contents**
- **Executive Summary**
- **Initial Statement and Additional Information Required by 18 CFR §4.32**
- [Exhibit A – Project Description](#)
- [Exhibit B – Project Operations and Resource Utilization](#)
- [Exhibit C – Construction History and Proposed Construction Schedule](#)
- [Exhibit D – Costs and Financing](#)

Volume II of III

- [Exhibit E – Environmental Report](#)
 - [Appendix I-2 – Consultation Summary \(Since Filing of the FLA\)](#)
 - [Appendix J – Bypass Reach Flow and Aquatic Habitat Usable Area Tables](#)

Volume III of III (CEII)

- [Exhibit F – General Design Drawings and Supporting Design Report](#)

⁴ By letter dated March 1, 2022, Appalachian distributed the draft HPMP to the Section 106 Consultation Distribution List for the Project and requested parties' concurrence on the draft HPMP. No responses have been received by Appalachian to date.

⁵ The Licensee's FLA filed February 28, 2022, contained five volumes. Exhibits that were pertinent to the FLA but were not modified since the FLA filing are not being re-filed in the amended FLA; these documents include Appendix A of Volume I (Flow Duration Curves), appendices to Exhibit E (Study Reports and Recreation Management Plan), Volume III (Exhibit F, G, and H), the Projects' single-line diagram, and Volume V (Cultural Resources Study Report and draft Historic Management Plan, filed as CUI with the FLA). These materials are referenced in the amended FLA by accession number in FERC's eLibrary where the material can be accessed.



Additional sections of the FLA⁶ that are not being revised and refiled with the amended FLA but are instead incorporated by reference are listed below:

FLA Volume I of V (Public) (Docket Number P-2514-209, Accession Number 20220228-5319)

- Executive Summary – Tables ES-1 and ES-2
- Exhibit B – Appendix A – Flow Duration Curves

FLA Volume II of V (Public) (Docket Number P-2514-209, Accession Number 20220228-5319, except where otherwise noted)

- Exhibit E –
 - Appendix A – Bypass Reach Flow and Aquatic Habitat Study (Docket Number P-2514-209, Accession Number 20220414-5077)
 - Appendix B – Water Quality Study
 - Appendix C – Aquatic Resources Study (Docket Number P-2514-209, Accession Number 20220414-5077)
 - Appendix D – Terrestrial Resources
 - Appendix E – Wetlands, Riparian, and Littoral Habitat Study
 - Appendix F – Shoreline Stability Study
 - Appendix G – Recreation Study
 - Appendix H – Recreation Management Plan
 - Appendix I – Consultation (through filing of the FLA)

FLA Volume III of V (Public) (Docket Number P-2514-209, Accession Number 20220228-5319)

- Exhibit F – List of General Design Drawings
- Exhibit G – Project Boundary Maps
- Exhibit H – Ability to Operate

FLA Volume IV of V (CEII) (Docket Number P-2514-209, Accession Number 20220228-5320)

- Exhibit H – Single-line Diagram

FLA Volume V of V (Controlled Unclassified Information/Privileged [CUI/PRIV]) (Docket Number P-2514, Accession Number 20220228-5321)

- Cultural Resources Study Report
- Draft Historic Properties Management Plan

Deleted: <#>Executive Summary¶
<#>Initial Statement and Additional Information Required by 18 CFR §4.32¶
<#>Exhibit A – Project Description¶

Deleted: Project Operations and Resource Utilization¶

Deleted: Exhibit C – Construction History and Proposed Construction Schedule¶
<#>Exhibit D – Costs and Financing¶

Deleted: Exhibit E – Includes the Environmental Report (Part 1) and all study reports as appendices (Part 2). Volume II also includes the draft Recreation Management Plan (Part 3), and documentation of consultation undertaken during this relicensing as appendices (Part 4). ¶

Deleted: (will be provided as supplemental information within 45-day of license filing)...

Deleted: (will be provided as supplemental information within 45-day of license filing)...

Deleted: Includes the list of design drawings filed as Critical Energy/Electric Infrastructure Information (CEII) in accordance with 18 CFR §388.112. The Design Drawings are included in Volume IV (CEII). A Supporting Design Report has been developed and is also included in Volume IV (CEII)....

Deleted: : Includes map showing the Project Boundary for the Byllesby-Buck Project. (Electronic Project Boundary files also included.)...

Deleted: <#>Exhibit H – Ability to Operate: Describes the commitment and responsibility of Appalachian as a Licensee to continue to operate and maintain the Project and the needs and costs for power from the Project or alternate sources. ¶

Deleted: <#>Exhibit F – General Design Drawings and Supporting Design Report¶

⁶ <https://elibrary.ferc.gov/eLibrary/docfamily?accessionnumber=20220228-5320&optimized=false>



[See Table ES-3 for a summary of the submittals \(as described above\) containing the license application components.](#)

Table ES-3. License Application Road Map

| Title | Document (Volume) |
|--|--------------------------|
| <ul style="list-style-type: none"> Table of Contents Executive Summary | Amended FLA (I of III) |
| <ul style="list-style-type: none"> Executive Summary – Tables ES-1 and ES-2 | FLA (I of V) |
| <ul style="list-style-type: none"> Initial Statement and Additional Information Required by 18 CFR §4.32 | Amended FLA (I of III) |
| Exhibit A – Project Description | Amended FLA (I of III) |
| Exhibit B – Project Operations and Resource Utilization | Amended FLA (I of III) |
| <ul style="list-style-type: none"> Flow Duration Curves | FLA (I of IV) |
| Exhibit C – Construction History and Proposed Construction Schedule | Amended FLA (I of III) |
| Exhibit D – Costs and Financing | Amended FLA (I of III) |
| Exhibit E – Environmental Report | Amended FLA (II of III) |
| <ul style="list-style-type: none"> Appendix A – Bypass Reach Flow and Aquatic Habitat Study Appendix B – Water Quality Study Appendix C – Aquatic Resources Study Appendix D – Terrestrial Resources Appendix E – Wetlands, Riparian, and Littoral Habitat Study Appendix F – Shoreline Stability Study Appendix G – Recreation Study Appendix H – Recreation Management Plan Appendix I – Consultation (through filing of the FLA) | FLA (II of V) |
| <ul style="list-style-type: none"> Appendix I-2 – Consultation Summary (Since filing of the FLA) Appendix J – Bypass Reach Flow and Aquatic Habitat Usable Area Tables | Amended FLA (II of III) |
| Exhibit F – List of General Design Drawings | FLA (III of V) |
| Exhibit F (CEII) – General Design Drawings and Supporting Design Report | Amended FLA (III of III) |
| Exhibit G – Project Boundary Maps | FLA (III of V) |
| Exhibit H – Ability to Operate | FLA (III of V) |
| Exhibit H (CEII) – Single-line Diagram | FLA (IV of V) |
| CEII: Cultural Resources Study Report, Draft HPMP | FLA (V of V) |

AMENDED FINAL LICENSE APPLICATION

BYLLESBY-BUCK HYDROELECTRIC PROJECT

(FERC No. 2514)

Initial Statement (18 CFR §4.51(a))



**BEFORE THE UNITED STATES OF AMERICA FEDERAL ENERGY REGULATORY
COMMISSION**

**BYLLESBY-BUCK HYDROELECTRIC PROJECT
(FERC No. 2514)**

**APPLICATION FOR A NEW LICENSE FOR A MAJOR WATER POWER PROJECT –
GREATER THAN 5 MEGAWATTS**

(1) Appalachian Power Company (Appalachian or Licensee or Applicant), a unit of American Electric Power (AEP) applies to the Federal Energy Regulatory Commission (FERC or Commission) for a new license for the Byllesby-Buck Hydroelectric Project (Project) (FERC Project No. 2514). The current license for the Project was issued on March 25, 1994 and expires on February 29, 2024.

(2) The location of the Project is:

| | |
|--------------------------------|---------------|
| State or territory: | Virginia |
| County: | Carroll |
| Township or nearby town: | City of Galax |
| Stream or other body of water: | New River |

(3) The exact name, address and telephone number of the applicant are:

Appalachian Power Company
Stephen A. Dolan
Plant Manager Hydro and Ceredo
American Electric Power Service Corporation
40 Franklin Road SW
Roanoke, Virginia 24011

(4) The exact name, address and telephone number of each person authorized to act as agent for the applicant in this application are:

Ms. Elizabeth B. Parcell
Process Supervisor
American Electric Power Service Corporation
40 Franklin Road SW
Roanoke, VA 24011
(540) 985-2441
ebparcell@aep.com

Mr. Jonathan Magalski
Environmental ~~Manager~~, Renewables
American Electric Power Service Corporation
1 Riverside Plaza
Columbus, OH 43215
(614) 716-2240
jmmagalski@aep.com

Deleted: Supervisor



- (5) The applicant is a domestic corporation and is not claiming preference under Section 7(a) of the Federal Power Act. See 16 U.S.C. 796.
- (6) The statutory or regulatory requirements of the state in which the Project is located that affect the Project as proposed with respect to bed and banks and the appropriation, diversion, and use of water for power purposes, and with respect to the right to engage in the business of developing, transmitting, and distributing power and in any other business necessary to accomplish the purposes of the license under the Federal Power Act are: Water rights involved are merely the riparian rights appurtenant, under Virginia law, to the various lands needed for dam site, flowage and tailrace purposes.

The Project was constructed and being utilized prior to 1928, the effective date of the (Virginia) Water Power Act and thus was exempted from the requirement that a license be obtained under the Act. Under said Act (Section 3581(13) of Michie Code 1942), all persons, firms, associations, or corporations who constructed and were utilizing their water power developments prior to 1928, and their lessees, successors and assigns, have, as to such developments and any reconstructions or enlargements thereof, all of the rights and powers conferred by the Act to the same extent as if they were licensees under the Act except that they do not have the power of eminent domain thereunder. By Section 62-88 of Chapter 5 of Title 62 of the Code of Virginia, the provisions of Section 3581(13) of Michie Code 1942 were continued in effect. Appalachian is incorporated under the laws of the Commonwealth of Virginia and qualified to do business as a public utility in Virginia.

The applicant will apply for the Section 401 Water Quality Certification per 18 Code of Federal Regulations (CFR) § 5.23(b). Under Section 401 of the Clean Water Act (CWA) (33 USC § 1251 et seq.), a federal agency may not issue a license or permit to conduct any activity that may result in any discharge into waters of the United States unless the state or authorized tribe where the discharge would originate either issues a Section 401 Water Quality Certification finding compliance with existing water quality requirements or waives the certification requirement. In the Commonwealth of Virginia, under § 62.1-44.15 of the Code of Virginia, the Virginia Department of Environmental Quality (VDEQ) provides Section 401 Water Quality Certification through the Virginia Water Protection (VWP) Program, as authorized by the State Water Control Law and as described in the VWP Permit Regulation. Appalachian is preparing a joint permit application for a VWP permit and surface water withdrawal for the continued operation of the Project in parallel with the FERC licensing process and intends, to the greatest extent possible, to use licensing documents including but not limited to study reports and the license application exhibits to satisfy this parallel regulatory process. Requirements for a VWP permit are described in 9 Virginia Administrative Code (VAC) 25-210-80 and 9VAC25-210-340.

- (7) Brief Project Description: Appalachian is the owner and operator of the two-development (Byllesby and Buck developments) Project located on the upper New River in Carroll County, Virginia. The Byllesby development is located about 9 miles north of the City of Galax, and the Buck development is located approximately three river miles downstream of Byllesby. The Project was constructed in 1912 and has been operated by Appalachian for hydroelectric power generation since 1926. Today the Project is operated by



Appalachian in a run-of-river manner, utilizing upper New River inflows to provide up to 30.1 megawatts (MW) of renewable capacity.

Presently licensed⁷ project works are as follows:

The Byllesby Development consists of: (1) a 64-foot-high, 528-foot-long concrete dam and main spillway section topped with four sections of 9-foot-high flashboards, five sections of 9-foot-high inflatable Obermeyer crest gates, and six bays of 10-foot-high Tainter gates; (2) an auxiliary spillway including six sections of 9-foot-high flashboards; (3) a 239-acre impoundment with a gross storage capacity of 2,000 acre-feet; (4) a powerhouse containing four generating units with a total authorized installed capacity of 21.6 megawatts (MW); and (5) appurtenant facilities.

The Buck Development consists of: (1) a 42-foot-high, 353-foot-long concrete dam; (2) a 1,005-foot-long, 19-foot-high spillway section topped with 20 sections of 9-foot-high flashboards, four sections of 9-foot-high inflatable Obermeyer crest gates, and six bays of 10-foot-high Tainter gates; (3) a 66-acre impoundment with a gross storage capacity of 661 acre-feet; (4) a powerhouse containing three generating units with a total authorized installed capacity of 8.5 MW; and (5) appurtenant facilities.

Additional existing facilities expected to be included as project works in the new license, as further explained in the exhibits that follow, include the following: (1) the Byllesby control house and switchyard, and (2) two 2-mile long overhead 13.2-kilovolt (kV) transmission lines extending from the Buck powerhouse to the Byllesby control house.

- (8) The Project Boundary for the transmission corridor, which under the existing license is a licensed Project feature but not included in the Project Boundary, encompasses 7.23 acres of federal lands (Jefferson National Forest).
- (9) The Project is an existing constructed project.

⁷ Authorized installed capacity values listed here are as presently licensed. Revisions to the existing authorized installed capacity values for the Project are described in Exhibit A.



Additional Information Required by 18 CFR § 4.32(a)(2)

(1) *Identify every person, citizen, association of citizens, domestic corporation, municipality, or state Identify every person, citizen, association of citizens, domestic corporation, municipality, or state that has or intends to obtain and will maintain any proprietary right necessary to construct, operate, or maintain the project:*

Appalachian presently holds and will continue to hold the proprietary rights necessary to operate and maintain the Project.

(2) *Identify (providing names and addresses):*

i. *Every county in which any part of the project, and any Federal facilities that would be used by the project would be located:*

| Name | Address |
|--------------------------|---|
| Carroll County, Virginia | Administrator Carroll County P.O. Box 515 Hillsville, VA 24343 |

ii. *The names and addresses of every city, town or similar local political subdivision in which any part of the Project, and any Federal facilities that would be used by the Project, are located or that has a population of 5,000 or more people and is located within fifteen (15) miles of the project dam are as follows:*

| Name | Address |
|------------------------------|---|
| City of Galax, Virginia | Mayor City of Galax Galax, Virginia 24333 |
| City of Pulaski, Virginia | Mayor City of Pulaski P.O. Box 660 Pulaski, Virginia 24330 |
| Town of Fries, Virginia | Manager Town of Fries P.O. Box 452 Fries, Virginia 24330 |
| Town of Hillsville, Virginia | Manager Town of Hillsville P.O. Box 545 Hillsville, Virginia 24343 |
| Town of Wytheville, Virginia | Manager Town of Wytheville P.O. Box 533 Wytheville, Virginia 24382 |
| Pulaski County, Virginia | Administrator |



| Name | Address |
|--------------------------|---|
| Grayson County, Virginia | Pulaski County 143 Third Street Pulaski, Virginia 24301 |
| Wythe County, Virginia | Administrator Grayson County P.O. Box 217 Independence, Virginia 24348 Administrator Wythe County 108 County Office Building 275 South Fourth Street Wytheville, Virginia 24382 |

There are no Federal facilities associated with the Project.

- iii. *Every irrigation district, drainage district, or similar special purpose political subdivision:*
 - A. *In which any part of the project, and any Federal facilities that would be used by the project, would be located, or (B) That owns, operates, maintains, or uses any project facilities or any Federal facilities that would be used by the project:*

There are no irrigation or drainage districts, or similar special purpose political subdivisions associated with or in the general area of the Project. There are no federal facilities associated with the Project.

- iv. *Every other political subdivision in the general area of the Project that there is reason to believe would likely be interested in, or affected by, the application.*

There are no other political subdivisions in the general area of the Project that there is reason to believe would likely be interested in, or affected by, the application.

- v. All Indian tribes that may be affected by the Project:

| Tribe | Address |
|-----------------------|--|
| Catawba Indian Nation | Wenonah Haire Tribal Historic Preservation Officer Catawba Indian Nation 1536 Tom Steven Rd. Rock Hill, SC 29730 |
| Delaware Nation | Erin Paden Director of Historic Preservation Delaware Nation PO Box 825 Anadarko, OK 73005 |
| Pamunkey Indian Tribe | Terry Clouthier Cultural Resources Director Pamunkey Indian Tribe 1054 Pocahontas Trail King William, VA 23086 |



VERIFICATION

This application is executed in the

State of: Virginia

County of: Roanoke

Stephen A. Dolan
Plant Manager Hydro and Ceredo
American Electric Power Service Corporation
40 Franklin Road SW
Roanoke, Virginia 24011

The undersigned being duly sworn, deposes and says that the contents of this application are true to the best of his knowledge or belief. The undersigned applicant has signed this application this 28th day of February, 2023.

Stephen A. Dolan

Subscribed and sworn to before me, a Notary Public of the Commonwealth of Virginia, this 28th day of February, 2023.

Notary Public

AMENDED FINAL LICENSE APPLICATION
BYLLESBY-BUCK HYDROELECTRIC PROJECT
(FERC No. 2514)

EXHIBIT A
PROJECT DESCRIPTION



Exhibit A - Project Description (18 CFR §4.51(b))

A.1 Project Overview and Location

Appalachian Power Company (Appalachian or Licensee), a unit of American Electric Power (AEP), is the Licensee, owner, and operator of the two-development Byllesby-Buck Hydroelectric Project (Project) (Federal Energy Regulatory Commission [FERC or Commission] Project No. 2514), located on the upper New River in Carroll County, Virginia.

The Byllesby Development (Byllesby) is located about nine miles north of the city of Galax, Virginia, on the New River. The primary facilities, including the powerhouse and spillway, are located within the Austinville, Virginia Quadrangle at approximately N. 36 deg., 47 min., 9 sec. and W. 80 deg., 56 min., 1 sec. The Buck Development (Buck) is located about 3 miles downstream from the Byllesby Dam. The primary facilities are located within the Austinville, Virginia Quadrangle at approximately N. 36 deg., 48 min., 20 sec. and W. 80 deg., 56 min., 4 sec.

Each development consists of a reservoir, concrete gravity dam and spillway, and powerhouse, and the Project also includes a control house and switchyard located at the Byllesby Development and two 2-mile-long 13.2-kilovolt (kV) overhead transmission lines connecting the two developments.

The Project is operated by Appalachian in a run-of-river manner, utilizing upper New River inflows to provide up to 30.1 megawatts (MW) of renewable capacity. Figure A.1-1 provides an overview of the Project setting and the FERC Project Boundary and Figure A.1-2 shows the location of the Project within the New River Basin.

All but one of the seven turbine-generator units installed at the Project are the original major components of the Project as constructed in 1912. Many of the major electrical and mechanical and supporting systems and components of the Project developments are nearing the end of their useful service life, when compared to industry-recognized standards. As described Section A.4 Appalachian proposes to modernize the Byllesby and Buck developments during the new license term to include replacement of Byllesby Units 1, 3, and 4 and Buck Units 1 and 3.

Deleted: 2




Figure A.1-1. Project Location Map




Figure A.1-2. Project Location on New River



A.2 Project Description

The Project was constructed in 1912 and has been operated by Appalachian for hydroelectric power generation since 1926.

The Byllesby Development [presently](#) consists of (1) a 64-foot [ft]-high, 528-ft-long concrete dam, sluice gate, and main spillway section topped with four sections of 9-ft-high flashboards, five sections of 9-ft-high inflatable Obermeyer crest gates, and six bays of 10-ft-high Tainter gates; (2) an auxiliary spillway including six sections of 9-ft-high flashboards; (3) a 239-acre reservoir with a gross storage capacity of approximately 2,000 acre-ft; (4) a powerhouse containing four generating units with a total authorized installed capacity of 18 MW; (5) a control house and switchyard; and (6) appurtenant facilities.

The Buck Development [presently](#) consists of (1) a 42-ft-high, 353-ft-long concrete dam and sluice gate; (2) a 1,005-ft-long, 19-ft-high spillway section topped with 20 sections of 9-ft-high flashboards, four sections of 9-ft-high inflatable Obermeyer crest gates, and six bays of 10-ft-high Tainter gates; (3) a 66-acre impoundment with a gross storage capacity of approximately 661 acre-ft; (4) a powerhouse containing three generating units with a total installed capacity of 8.087 MW; (5) a two 2-mile long overhead 13.2-kV transmission lines extending from the Buck powerhouse to the Byllesby control house; and (6) appurtenant facilities (FERC 2017).

Each development recently underwent modification as approved by an order amending license issued by FERC on May 18, 2017 to replace several sections of existing wooden flashboards with inflatable Obermeyer pneumatic crest gates. The Obermeyer crest gates facilitate smoothing Project operations by reducing reservoir water level fluctuations and instances of inadvertent flow to the bypass reaches and reducing the frequency of maintenance drawdowns associated with wooden flashboard failure and replacement.

[In the new license term, Appalachian plans to replace several wooden flashboard sections at each of the Byllesby and Buck developments with inflatable Obermeyer gates. As proposed, three flashboard sections at the Byllesby Development \(one on the main spillway, and two on the auxiliary spillway\) and six sections at the Buck Development \(four adjacent to the existing Obermeyer gates and two nearer the left abutment of the spillway\) will be replaced. Appalachian is also proposing to operate Obermeyer gates to provide a continuous bypass reach minimum flow of approximately 35 cfs at the Byllesby Development and a seasonal \(February 15th – May 15th\) continuous bypass reach minimum flow of approximately 100 cfs at the Buck Development.](#)



The facilities and structures listed above are described in the sections that follow, are depicted on Figure A.2-1 and Figure A.2-2, and are also shown on the project drawings included in Exhibit F (filed as Critical Energy/Electric Infrastructure Information [CEII] in accordance with 18 CFR §388.112) of this [amended](#) Final License Application (FLA).



Figure A.2-1. Existing Project Facilities – Byllesby Development




Figure A.2-2. Existing Project Facilities – Buck Development



A.3 Existing Project Facilities

A.3.1 Reservoirs

A.3.1.1 *Byllesby Development*

The Byllesby Development is operated year-round in a run-of-river mode under all flow conditions. Under normal operating conditions, Appalachian operates Byllesby to maintain the headwater between EL. 2,079.2 and 2,078.2 ft⁸. Byllesby has little storage capacity or ability to regulate river flow; inflow is either used for generation or passed through the spillway.

The normal maximum surface area of the reservoir formed by the Byllesby dam is 239 acres at a normal maximum surface EL. 2079.2 ft. The corresponding gross storage capacity of the Byllesby reservoir is approximately 2,000 acre-ft, and the usable storage capacity in the upper 5.2 ft of the pool is approximately 1,153 acre-ft. Table A.3-1 contains Byllesby Development reservoir data. A reservoir storage capacity curve is included in Exhibit B.

Table A.3-1. Byllesby Development Reservoir Data

| | |
|--|--------------------|
| Drainage area | 1,310 square miles |
| Shoreline length | 16.8 miles |
| Typical surface area | 239 acres |
| Maximum Depth | 35 ft |
| Permanent crest of dam elevation | 2,071 ft NGVD |
| Typical normal surface water elevation | 2079.2 ft NGVD |
| Operations | Run-of-river |
| Gross Storage capacity | 2,000 acre-ft |

A.3.1.2 *Buck Development*

The Buck Development is operated year-round in a run-of-river mode under all flow conditions. Under normal operating conditions, Appalachian operates Buck to maintain the headwater between EL. 2,003.4 and 2,002.4 ft. Buck has little storage capacity or ability to regulate river flow; inflow is either used for generation or passed through the spillway. Because the Buck Development is only approximately three miles downstream from the Byllesby Development, the operation of the two

⁸ All elevations are referenced to national Geodetic Vertical Datum of 1929 (NGVD)

developments is closely coordinated, with Buck Development operations dependent on flows through the Byllesby Development.

The Buck reservoir has a surface area of approximately 66 acres at a normal maximum pool EL. 2,003.4 ft.). The corresponding gross storage capacity of the Buck reservoir is approximately 661 acre-ft, and the usable storage capacity in the upper 8.4 ft of the pool is approximately 579 acre-ft. Table A.3-2 contains Buck Development reservoir data. A reservoir storage capacity curve is included in Exhibit B.

Table A.3-2. Buck Development Impoundment Data

| Drainage area | 1,320 square miles |
|--|--------------------|
| Shoreline length | 5.8 miles |
| Typical surface area | 66 acres |
| Maximum Depth | 20 ft |
| Permanent crest of dam elevation | 1995 ft NGVD |
| Typical normal surface water elevation | 2003.4 ft NGVD |
| Operations | Run-of-river |
| Gross Storage capacity | 661 acre-ft |

A.3.2 Spillway and Dam

A.3.2.1 Byllesby Development

Water-impounding or controlling structures at the Byllesby Development include a main dam/spillway topped with Tainter gates, inflatable Obermeyer crest gates, and flashboard sections; a trash sluice gate; a powerhouse; and an auxiliary (or emergency) spillway surmounted by flashboards. The main spillway extends across the New River perpendicular to the flow. The spillway is a solid, concrete, gravity-type structure approximately 528 ft long by 44 ft high from toe to crest. The crest of the spillway is at elevation 2071 ft. Topping the main spillway, beginning at the western end, are six radial Tainter gates (Bays 1 – 6), three [stanchion type \(wooden\) flashboard bays](#) (Bays 7 – 9), five inflatable Obermeyer crest gates (Bays 10 – 14)⁹, and one additional [stanchion type \(wooden\) flashboard bay](#) (Bay 15). [In the new license term, Appalachian plans to replace the wooden flashboards in Bay 9 with an inflatable Obermeyer crest gate of the same design and dimensions.](#)

Deleted: wooden flashboard section

Deleted: wooden flashboard section

Deleted: The spillway gate configuration is shown on Figure A.3-1....

⁹ The first Obermeyer gate was installed in 1998 to replace the flashboards in Bay 14. Two additional bays of Obermeyer gates were installed in 2016 (Bays 12 and 13) and 2018 (Bays 10 and 11).



Each bay is supported by reinforced-concrete piers and is approximately 31 ft, 4 inches wide. The gates and flashboards have a total height of approximately 9 ft. The Tainter gates consist of a steel gate with a radius of 11 ft, 3 inches supported by reinforced-concrete piers. Each gate rotates on a pin. Each Obermeyer gate is also approximately 31 ft, 4 inches wide. The Tainter gates and are opened and closed by means of a hoist powered by an electric motor, and the Obermeyer gates are operated with air compressors installed inside the powerhouse that provide for redundant inflation of the air bladders via stainless steel piping that conveys the compressed air from the receiver tank to the Obermeyer control enclosure. The Tainter gates and Obermeyer gates can be remotely monitored and operated from AEP's 24-hour Columbus Operations Center (COC) in Columbus, Ohio. A propane-powered auxiliary generator is available to support spillway gate operation in case of an electrical outage. A steel-grated foot bridge supported by steel beams on the concrete piers runs the length of the main spillway.

The auxiliary spillway is located upstream and to the west of the powerhouse and to the west of the main spillway. The auxiliary spillway is connected to the powerhouse by an angled 77-ft-long non-overflow bulkhead (or "wingwall") with a crest elevation of 2,085.0 ft and a structural height that varies from 24 ft to 43 ft. The auxiliary spillway is a concrete structure approximately 198 ft long and 6.5 ft high from toe to crest. It is [presently topped by six spans of flashboards \(Bays A - F\) approximately 9 ft high. In the new license term, Appalachian plans to replace the wooden flashboards in Bays E and F with inflatable Obermeyer crest gates of the same design and dimension as those presently installed on the main spillway.](#) Reinforced-concrete piers support the flashboard sections and an access bridge. The existing access bridge is of metal grating grouted with concrete atop steel beams. The auxiliary spillway discharges into a 600-ft-long channel, excavated from rock, which curves around and empties into the New River further downstream. [The existing spillway gate configurations are shown on Figure A.3-1, and the proposed spillway gate configurations are shown on Figure A.3-2.](#) The spillway capacity curve for the Byllesby Development is provided in Exhibit B.




Figure A.3-1. Bylesby Dam Spillway Gates (Existing)




Figure A.3-2. Byllesby Dam Spillway Gates (Proposed)



A.3.2.2 Buck Development

Water-impounding or controlling structures at the Buck Development consist of spillway and main dam sections separated by Mountain (or Buck) Island that is bedrock controlled. The spillway section is located on the south side of the island. From left to right, the spillway section presently consists of 18 stanchion type (wooden) flashboard bays (Bays 11 – 28), four Obermeyer gate bays (Bays 7 – 10), six Tainter gate bays (Bays 1 – 6), and two additional flashboard bays (Bays A – B). To the right of the spillway and approximately 1,300 ft downstream, and on the opposite side of Mountain Island, the 352-ft-long by 44-ft-high main dam consists of a left non-overflow (South Bulkhead) section, powerhouse with integral intake, a trash sluice with a vertical slide gate, and right non-overflow (North Bulkhead) section. The normal headwater at both sections ranges from EL. 2,002.41 ft to 2,003.4 ft. The normal tailwater elevations at the spillway and main dam sections are EL. 1,980.0 ft and 1,962.7 ft, respectively.

Deleted: is

The spillway, similar to the Byllesby spillway, is a solid, concrete, gravity-type structure approximately 1,005 ft long by 19 ft high from base to crest. The crest of the spillway is at EL. 1,995 ft. The spillway is flanked at both contacts by non-overflow wingwalls. The spillway is topped with a bridge, constructed of precast, pre-stressed concrete beams, supported atop the spillway gate piers. Topping the spillway, beginning at the northwestern end, are two wooden flashboard sections (Bays A – B) supported by reinforced-concrete piers, with widths of 31 ft, 10 inches and 32 ft, 10 inches, respectively, and a height of approximately 9 ft. Adjacent to the flashboard sections are six radial Tainter gate bays (Bays 1 – 6). Each Tainter gate bay is approximately 31 ft, 4 inches wide and contains a steel gate of radius 11 ft, 3 inches supported by reinforced-concrete piers. The gates rotate on a pin and are opened and closed by means of a hoist powered by an electric motor. Adjacent to the Tainter gates are four inflatable Obermeyer crest gates (Gates 7 – 10), with each Obermeyer gate measuring 9.2-ft-high by 31.3-ft-wide. The Obermeyer gates are operated with air compressors that provide for redundant inflation of the air bladders. Due to the distance of the spillway from the powerhouse, during installation of the first two Obermeyer gates in 2017, two new air compressors were installed in a newly constructed building adjacent to the spillway, with new stainless steel piping installed to convey the compressed air from the receiver tank to the Obermeyer control enclosure. Both the Tainter gates and Obermeyer gates can be remotely monitored and operated from AEP's 24-hour control COC. A propane-fueled auxiliary generator is available to support spillway gate operation in case of an electrical outage. In the new license term, Appalachian plans to replace the wooden flashboards in Bays 11 – 14 and 25 and 26 with inflatable Obermeyer crest gates of the same design and dimensions. The existing spillway gate configuration is shown on Figure A.3-3, and the proposed spillway gate configuration is shown on Figure A.3-4. The spillway capacity curve for the Buck Development is provided in Exhibit B.

Deleted: Gates

Deleted: The spillway gate configuration is shown on Figure A.3-2. ¶




Figure A.3-3. Buck Dam Spillway Gates (Existing)




Figure A.3-4. Buck Dam Spillway Gates (Proposed)



A.3.3 Low-Level Outlets and Sluice Gates

A.3.3.1 Byllesby Development

The sluice gate section is a 24-ft-long mass concrete gravity structure located between the powerhouse and main spillway sections and founded directly on bedrock. In 1993, two post-tensioned rock anchors were installed through the downstream face at approximate EL. 2,073.5 and 2,077.2 ft, respectively. The crest of the sluice gate section is at EL. 2,085.0 ft corresponding to a structural height of 63.0 ft. When the Project was originally constructed in 1912, two mud sluice gates were installed between the Byllesby powerhouse and the main spillway. These mud gates have since been taken out of service and concreted in. A steel plate vertical drop gate approximately 6-ft-10 ¼-inch wide by 5-ft high has since been installed in the slots of the western-most mud sluice. This gate is manually lowered and raised by an electric motor-powered hoist.

A.3.3.2 Buck Development

A 36-foot-long sluice gate section is located between the powerhouse and the right non-overflow section. The sluice gate section is constructed of mass concrete socketed into bedrock at and bearing at approximate EL. 1,965.0 ft. In 1993, three vertical post-tensioned rock anchors were installed through the crest at EL. 2,007 ft. The crest of the sluice section is at elevation 2,007.0 ft corresponding to a structural height of 42.0 ft. As for Byllesby, during original Project construction in 1912, two mud sluices and a vertical lift gate were installed in the main dam, immediately adjacent to the north end of the powerhouse. The mud sluices were reportedly abandoned with concrete in-fill in 1930. The sluice gate section also includes a 6-ft-wide by 14-ft-high vertical slide gate, which is manually operated as required to pass flotsam and debris through the sluice.

A.3.4 Forebay and Intake

A.3.4.1 Byllesby Development

The intake section, located immediately upstream of the powerhouse, consists of four inlet bays. Each bay has a 14.5-ft-high by 23-ft-wide headgate, which is used during maintenance periods. A 3-ft-wide, reinforced-concrete pier is set vertically in the middle of each inlet bay to support the headgate. Each headgate is closed and opened by a gear and screw lift shaft assembly powered by an electric motor. Each bay admits water to a concrete volute casing, which channels flow to a vertical-shaft Francis hydraulic turbine direct-connected to a generator on the upper level. Flow through the four turbines passes to concrete draft tubes and into the New River.

The intake section at Byllesby is faced with an intake screen approximately 143 ft wide and consisting of 3/8-inch by 3-1/2-inch steel bars. The bars are 47 ft, 6-3/8 inches long and are inclined



toward the powerhouse at approximately 15 degrees to the vertical. The bars are spaced 2-21/32 inches center-to-center and have a cleared space of 2-9/32 inches.

A logboom consisting of interconnected floating platforms diverts large objects carried by the current away from the powerhouse intakes. The logboom, which is approximately 140 ft long, is anchored on land at one end and adjacent to the vertical drop trash sluice gate on the other end.

A.3.4.2 Buck Development

The Buck intake section, which is immediately upstream of the powerhouse, is of concrete construction and consists of three inlet bays. Each bay has a 14.5-ft-high by 23-ft-wide headgate which is used during maintenance periods. A 3-ft-wide, reinforced-concrete pier is set vertically in the middle of each inlet bay to support the headgate. Each gate is operated by a gear and threaded lift shaft assembly powered by an electric motor. The bays admit water to a concrete volute casing, which channels flow to a vertical-shaft Francis hydraulic turbine, direct-connected to a generator on the upper level. Flow through the three turbines passes to concrete draft tubes and into the New River.

The intake section at Buck is faced with an intake screen approximately 104 ft wide and consisting of 3/8-inch by 3-1/2-inch steel bars. The screen is 39 ft, 2-1/16 inches high and is inclined toward the powerhouse at approximately 15 degrees to the vertical. The bars are spaced 2-21/32 inches center-to-center and have a cleared space of 2-9/32 inches.

A logboom consisting of interconnected floating platforms diverts large objects carried by the current away from the powerhouse intakes. The logboom is anchored at one end to the north shore of Mountain Island, approximately 580 ft upstream of the main dam. The logboom spans approximately 620 ft and anchors at the other end, adjacent to the vertical lift trash sluice gate.

A.3.5 Bypass Reach

A.3.5.1 Byllesby Development

The Byllesby Development includes a 590-ft-long bypass reach consisting primarily of exposed bedrock and rock outcroppings. This reach normally receives only leakage flow, unless flows are being spilled at the dam or the flashboards are breached. [In the new license term, for the protection of aquatic resources, Appalachian proposes to provide a continuous bypass reach minimum flow of approximately 35 cfs from any one or combination of the Obermeyer gates installed on the main spillway.](#)



A.3.5.2 Buck Development

The Buck Development has a 4,100-ft-long, steep bypass reach consisting of exposed bedrock. This reach normally receives only leakage flow, unless flows are being spilled at the dam or the flashboards are breached. In the new license term, for the protection of Walleye during spawning season, from February 15th – May 15th annually, Appalachian proposes to provide a continuous bypass reach minimum flow of approximately 100 cfs from Obermeyer gates in Bay 25 and/or 26.

Deleted: at

A.3.6 Powerhouse

A.3.6.1 Byllesby Development

The Byllesby powerhouse is located to the west of the main spillway. The powerhouse is a 151-ft-long reinforced concrete water retaining structure with a 170-ft-long steel frame and brick superstructure. Four generators and their respective governors and exciters, pumps, a gantry crane and miscellaneous accessory equipment necessary for operation are housed in the upper level of the powerhouse. The powerhouse is supported directly on bedrock. The intake invert is at EL. 2,040.0 ft and the deck is at EL. 2,085.0 ft. The upstream substructure wall is integral with both the left non-overflow structure to the left and sluice gate section to the right. There are no means for passing flows through the powerhouse other than through the turbines. The vertical drop sluice gate, located between the powerhouse and main spillway sections, provides the closest spill location, but this release is to the spillway tailwater and not the powerhouse tailrace.

A.3.6.2 Buck Development

The powerhouse, located at the main dam, includes a 116-ft-long reinforced concrete water retaining substructure with a 132-ft-long steel frame and brick superstructure. The powerhouse has two levels. Three generators, and their respective governors and exciters, switchboards, switching equipment, pumps, a gantry crane and miscellaneous accessory equipment necessary for project operation are housed in the upper level of the powerhouse. The powerhouse is supported directly on bedrock at approximate EL. 1,964 ft. The intake invert is at EL. 1,969 ft and upstream intake deck slab is at EL. 2,007.0 ft. The substructure walls are integral with the left non-overflow section and sluice gate section to the right. There are no means for passing flows through the powerhouse other than through the turbines. Flows to the Buck tailrace can be provided via the vertical slide gate located in the sluice section located between the powerhouse and the right non-overflow section.



A.4 Existing and Proposed Turbines and Generators

A.4.1 Authorized Installed Capacity - Existing

The Project's installed capacity is presently considered by FERC to be 30.1 MW, representing 21.6 MW at Byllesby and 8.5 MW at Buck (Appalachian 2019). These values are based on the capacities of the generators, which was the basis for installed capacity at the time of the last relicensing. Based on the installed nameplate ratings and the method now used by FERC to calculate authorized installed capacity (18 CFR §11.1(i)), the existing installed capacities for the Byllesby and Buck developments, should be considered 18 MW and 8.087 MW, respectively, for a total authorized installed capacity of 26.087 MW. A summary of existing and proposed, as described and proposed below, authorized installed capacities for both developments is provided at the end of this section in Table A.4-5.

A.4.2 Byllesby Development

A.4.2.1 Existing Equipment

The powerhouse contains four, vertical Francis-type turbine generator units (Nos. 1 through 4 from right to left) under a normal gross head of 56.4 ft, each direct-connected to a generator on the upper level. The turbine units were manufactured by I.P. Morris Company in 1912 and contain 16 buckets per runner. The edge-to-edge diameter of the runners is 8-ft 9-inches measured at the bottom of the runner, inside the band. There are 20 cast iron wicket gates at each hydraulic turbine with heights of 2-ft 11-inches to 15/16-inches each. The wicket gates are placed in a circular pattern at a radial dimension of 4-ft 11-inches from the centerline of the turbine shaft to the pivot point of each gate. By adjusting the openings between the wicket gates, flow to the turbine is controlled. Outside of the wicket gates are ten stay vanes arranged in a circular pattern at a radial distance of 7 ft from the centerline of the turbine shaft to the leading edge of the stay vane. The stay vanes are stationary and are used to control the direction of flow and to support the structure overhead.

Maximum flow of 1,467 cubic ft per second (cfs) through each unit (total capacity of 5,868 cfs) is discharged through four draft tubes into a 300-ft-long tailrace defined by the bedrock outcrop (island) on the left and a concrete training wall on the right. The right training wall separates the powerhouse discharge from the main spillway. In 1993, 12 vertical post-tensioned rock anchors (P-1 through P-12) were installed through the piers on the upstream side of the intake deck at elevation 2,085.0 ft.

Each Byllesby turbine is rated at 6,000 horsepower (hp) at a 49 ft design head and has a rated speed of 116 rotations per minute (rpm). Based on design curves, one unit can pass 1,467 cfs at 5,265 kilowatt (kW) turbine-generator output and a 56 ft net head.

Deleted: 360

Deleted: 440



The four AC generators, located in the upper level of the Byllesby powerhouse, are identical and were manufactured by the General Electric Company. These generators have been in service since 1912. They are rated at 5,400 kW at 90 percent power factor, 3 phase (PH), 60 cycles and 13,200 volts (V). Each 62 pole generator has a rotor speed of 116 rpm at 60 Hertz (Hz).

Each generator has an inside diameter of 13-ft 4-inch and contains 93 coils. Each coil slot is 42 and 1/8 inches high by 1.45 inches wide by 2.93 inches deep. Pertinent turbine and generator data for Byllesby is included in Table A.4-1.¹⁰

Table A.4-1. Byllesby Development Turbine and Generator Data - Existing

| <i>Turbines</i> | |
|-------------------|--|
| Number of Units | 4 |
| Type | Vertical Francis, I.P. Morris Co. |
| Design Head | 49 ft |
| Rated Capacity | 6,000 hp / 4,500 kW (each unit) |
| Minimum Discharge | 73 cfs (per unit) (350 cfs at 37% efficiency and design head) |
| Maximum Discharge | 1,467 cfs (per unit) |
| Operating Speed | 116 rpm |
| <i>Generators</i> | |
| Type | Vertical configuration, General Electric Co. |
| Rated Capacity | 5,400 kW (per unit) |
| Power Factor | 0.9 |
| Phase | 3 PH (per unit) |
| Voltage | 13,200 V (per unit) |
| Frequency | 60 Hz (per unit) |
| Synchronous Speed | 116 rpm (per unit) |

Deleted: 325

A.4.2.2 Proposed Upgrade

All of the turbine-generator units at the Byllesby Development are the original major components of the Project as constructed in 1912. Unit 4 is presently off-line and has been deemed by Appalachian to be non-repairable. Many of the major electrical and mechanical and supporting systems and

¹⁰ [The minimum unit discharges for the existing equipment provided in Exhibit A of the FLA were incorrect and were provided in the AIR response filed by Appalachian on September 8, 2022.](#)



components at Byllesby are nearing the end of their useful service life, when compared to industry-recognized standards. Appalachian proposes to modernize the Byllesby Development during the new license term to include replacement of Byllesby Units 1, 3 and 4. Byllesby Unit 2 would remain as-is and, following completion of the upgrades, would be operated in a last-on/first-off sequence.

Deleted: 2,
Deleted: 3

Appalachian proposes to replace each existing vertical Francis turbine with a vertical Kaplan turbine. The most efficient point (MEP) operation setting for each new unit at the design head of 54 ft is 91.69 turbine efficiency, representing a unit discharge of approximately 1,348 cfs. The new Kaplan turbines would each have 5 runner blades, 16 wicket gates, and a runner diameter of 8.7 ft.

Each turbine upgrade will include:

- Mavel KV2650K5 Kaplan turbine including stay ring, operating ring, wicket gate mechanism, upper distributor ring, and wicket gates;
- Hydraulic Power Unit (HPU) with accumulator tank for control of the wicket gates, blades, and brake;
- Wicket gate, blade, and brake servomotors;
- Sensors for control and monitoring of the turbine;
- Steel portion of a replacement section of the draft tube;
- Civil work as needed to facilitate installation; and
- Controls, cabling, switchgear, and other electrical work.

Appalachian is also presently proposing to replace each generator. The highest efficiency point of the new generators would be approximately 96.9 percent at 100 percent load.

Proposed upgraded turbine and generator parameters for the Byllesby Development are presented in Table A.4-2.



Table A.4-2. Byllesby Development Turbine and Generator Data – Proposed (Upgrades to Units 1, 3 and 4)

| Turbines | |
|-------------------|---|
| Number of Units | 4 |
| Type | Units 1, 3 and 4: Vertical Kaplan, Mavel Unit 2: Vertical Francis, I.P. Morris Co. |
| Design Head | Units 1, 3 and 4: 56 ft Unit 2: 49 ft |
| Rated Capacity | Units 1, 3, and 4: 7,371 hp / 5,528 kW (per unit) Unit 2: 6,000 hp / 4,500 kW |
| Minimum Discharge | Units 1, 3, and 4: 350 cfs (per unit) ¹¹ Unit 2: 73 cfs (350 cfs at 37% efficiency and design head) |
| Maximum Discharge | Units 1, 3, and 4: 1,348 cfs (per unit) Unit 2: 1,467 cfs |
| Operating Speed | Units 1, 3, and 4: 189.47 rpm Unit 2: 116 rpm |
| Generators | |
| Type | Units 1, 3, and 4: Vertical configuration, Mavel Unit 2: Vertical configuration, General Electric Co. |
| Rated Capacity | Units 1, 3, and 4: 5,885 kVA / 5,296.5 kW (per unit) Unit 2: 5,400 kW (per unit) |
| Power Factor | 0.9 |
| Phase | 3 PH (per unit) |
| Voltage | 13,200 V (per unit) |
| Frequency | 60 Hz (per unit) |
| Synchronous Speed | Units 1, 3, and 4: 189.47 rpm (per unit) Unit 2: 116 rpm |

Deleted: Units 1, 2,

Deleted: Units 1, 2,

Deleted: 3

Deleted: Units 1, 2,

Deleted: 3

Deleted: 2

Deleted: 3

Deleted: 2

Deleted: 3

Deleted: 325

Deleted: 2

Deleted: 3

Deleted: 2

Deleted: 3

Deleted: 2

Deleted: 3

Deleted: 2

Deleted: 3

Deleted: 2

Deleted: 3

¹¹ Appalachian notes that the minimum discharge values provided for the proposed turbine upgrades are the lowest values on the preliminary turbine efficiency curves provided by the manufacturer. Appalachian expects the actual minimum discharge for the upgraded units will be as low as the minimum discharge associated with the existing units, or lower. Appalachian plans to file these values with the Commission along with other as-built specifications for the upgraded turbines following final turbine specifications, installation, and commissioning.

Deleted: that

Deleted: would



A.4.3 Buck Development

A.4.3.1 Existing Equipment

Within the substructure of the Buck powerhouse are housed three vertical-shaft Francis hydraulic turbines, each direct-connected to a generator on the upper level. The three turbine units at Buck were manufactured by I.P. Morris Company in 1912. Unit 2 was refurbished in 2006 with an in-kind American Hydro runner replacement. The dimensions and configuration of each turbine's runner, wicket gates and stay vanes are identical to those of the Byllesby turbine units. Maximum flow of 1,180 cfs through each unit (total capacity of 3,540 cfs) is discharged through three draft tubes into the tailrace channel that was excavated into bedrock. Based on design curves, one unit can pass 1,180 cfs at 3,158 kW turbine-generator output and a 40 ft net head. In 1993, seven vertical post-tensioned rock anchors were installed through the concrete piers on the upstream side of the intake deck at elevation 2,007 ft. Each of the three turbines at Buck is rated at 3,500 hp at a 34 ft design head and has a rated speed of 97 rpm.

The three AC generators, located in the upper level of the Buck Powerhouse, are identical and were manufactured by the General Electric Company. These generators have been in service since 1912. They are rated at 2,835 kW at 90 percent power factor, 3 PH, 60 cycles and 13,200 V. Each 74 pole generator has a rotor speed of 97 rpm at 60 Hz.

Each generator stator has an inside diameter of 15-ft 10-inches and contains 222 coils. Each coil slot is 23 and 7/8 inches high by 1.312 inches wide by 3.75 inches deep. The Buck Development has a total installed capacity of 8.087 MW. The turbines discharge into a tailrace channel that is approximately 1,700 ft long and 70 ft wide. The depth of the channel is fairly uniform downstream of the immediate vicinity of the powerhouse, averaging 6.5 to 10 ft at a point 160 ft downstream of the powerhouse. Pertinent turbine and generator data for the Buck Development is included in Table A.4-3.¹²

Deleted: d

¹² [The minimum unit discharges for the existing equipment provided in Exhibit A of the FLA were incorrect and were provided in the AIR response filed by Appalachian on September 8, 2022.](#)



Table A.4-3. Buck Development Turbine and Generator Data - Existing

| <i>Turbines</i> | |
|-------------------|--|
| Number of Units | 3 |
| Type | Units 1 and 3: Vertical Francis, I.P. Morris Co. Unit 2: American Hydro |
| Design Head | 34 ft |
| Rated Capacity | Units 1 and 3: 3,500 hp / 2,626 kW Unit 2: 4,480 hp / 3,360 kW |
| Minimum Discharge | <u>60 cfs (per unit) (275 cfs at 50% efficiency and design head)</u> |
| Maximum Discharge | 1,180 cfs (per unit) |
| Operating Speed | 97 rpm |
| <i>Generators</i> | |
| Type | Vertical configuration, General Electric Co. |
| Rated Capacity | 2,835 kW (per unit) |
| Power Factor | 0.9 |
| Phase | 3 PH (per unit) |
| Voltage | 13,200 V (per unit) |
| Frequency | 60 Hz (per unit) |
| Synchronous Speed | 97 rpm (per unit) |

Deleted: 275

A.4.3.2 Proposed Upgrade

Two of three turbine-generator units at the Buck Development are the original major components of the Project as constructed in 1912. Many of the major electrical and mechanical and supporting systems and components at Buck are nearing the end of their useful service life, when compared to industry-recognized standards. Appalachian proposes to modernize the Buck Development during the new license term to include replacement of Buck Units 1 and 3.

Appalachian proposes to replace two of the existing vertical Francis turbine with vertical Kaplan turbines. The MEP operation setting for each new unit at a design head of 42.4 ft is 91.59 turbine efficiency, representing a unit discharge of approximately 930 cfs. The new Kaplan turbines would each have 5 runner blades, 16 wicket gates, a runner diameter of 8.7 ft, and a runner setting of 1,981.89 ft.

Each turbine upgrade will include:

- Mavel KV2650K5 Kaplan turbine including stay ring, operating ring, wicket gate mechanism, upper distributor ring, and wicket gates;



- HPU with accumulator tank for control of the wicket gates, blades, and brake;
- Wicket gate, blade, and brake servomotors;
- Sensors for control and monitoring of the turbine;
- Steel portion of a replacement section of the draft tube;
- Civil work as needed to facilitate installation; and
- Controls, cabling, switchgear, and other electrical work.

Appalachian is also presently proposing to replace each generator. The highest efficiency point of the new generators would be approximately 96.9 percent at 100 percent load.

Proposed upgraded turbine and generator parameters for the Buck Development are presented in Table A.4-4.



Table A.4-4. Buck Development Turbine and Generator Data – Proposed (Upgrades to Units 1 and 3)

| <i>Turbines</i> | |
|-------------------|--|
| Number of Units | 3 |
| Type | Units 1 and 3: Vertical Kaplan, Mavel Unit 2: Vertical Francis, American Hydro |
| Design Head | Units 1 and 3: 42.4 ft Unit 2: 34 ft |
| Rated Capacity | Units 1 and 3: 4,400 hp / 3,300 kW (per unit) Unit 2: 4,480 hp / 3,360 kW |
| Minimum Discharge | Units 1 and 3: 300 cfs (per unit) ¹³ Unit 2: 60 cfs (275 cfs at 50% efficiency and design head) |
| Maximum Discharge | Units 1 and 3: 1,195 cfs (per unit) Unit 2: 1,180 cfs |
| Operating Speed | Units 1 and 3: 156.52 rpm Unit 2: 97 rpm |
| <i>Generators</i> | |
| Type | Units 1 and 3: Vertical configuration, Mavel Unit 2: Vertical configuration, General Electric Co. |
| Rated Capacity | Units 1 and 3: 4,100 kVA / 3,690 kW (per unit) Unit 2: 2,835 kW |
| Power Factor | 0.9 |
| Phase | 3 PH (per unit) |
| Voltage | 13,200 V (per unit) |
| Frequency | 60 Hz (per unit) |
| Synchronous Speed | Units 1 and 3: 156.52 rpm Unit 2: 97 rpm |

Deleted: 27

Deleted: 5

A.4.4 Authorized Installed Capacity - Proposed

Table A.4-5 presents a comparison of the existing and proposed authorized installed capacities for the existing and proposed units. Based on the installed nameplate ratings and the method used by FERC to calculate authorized installed capacity (18 CFR §11.1(i)), with the proposed upgrades, the authorized installed capacities for the Byllesby and Buck developments will be 20.3895 MW and 9.435 MW, respectively, for a total authorized installed capacity of 29.8245 MW.

¹³ Appalachian notes the minimum discharge values provided for the proposed turbine upgrades are the lowest values on the preliminary turbine efficiency curves provided by the manufacturer. Appalachian expects the actual minimum discharge for the upgraded units will be as low as the minimum discharge associated with the existing units, or lower. Appalachian plans to file these values with the Commission along with other as-built specifications for the upgraded turbines following final turbine specifications, installation, and commissioning.



Table A.4-5. Existing and Proposed Unit Comparison

| Development | Unit | Existing Units | | | | Proposed Units | | | |
|--------------|--------------|---------------------|---------------------------------|-----------------------|------------------------------------|---------------------|---------------------------------|-----------------------|------------------------------------|
| | | Turbine Rating (kW) | Maximum Turbine Discharge (cfs) | Generator Rating (kW) | Authorized Installed Capacity (kW) | Turbine Rating (kW) | Maximum Turbine Discharge (cfs) | Generator Rating (kW) | Authorized Installed Capacity (kW) |
| Byllesby | 1 | 4,500.0 | 1,467.0 | 5,400.0 | 4,500.0 | 5,528.0 | 1,348.0 | 5,296.5 | 5,296.5 |
| | 2 | 4,500.0 | 1,467.0 | 5,400.0 | 4,500.0 | 4,500.0 | 1,467.0 | 5,400.0 | 4,500.0 |
| | 3 | 4,500.0 | 1,467.0 | 5,400.0 | 4,500.0 | 5,528.0 | 1,348.0 | 5,296.5 | 5,296.5 |
| | 4 | 4,500.0 | 1,467.0 | 5,400.0 | 4,500.0 | 5,528.0 | 1,348.0 | 5,296.5 | 5,296.5 |
| | Total | 18,000.0 | 5,868.0 | 21,600.0 | 18,000.0 | 21,084.0 | 5,511.0 | 21,289.5 | 20,389.5 |
| Buck | 1 | 2,626.0 | 1,180.0 | 2,835.0 | 2,626.0 | 3,300.0 | 1,195.0 | 3,690.0 | 3,300.0 |
| | 2 | 3,360.0 | 1,180.0 | 2,835.0 | 2,835.0 | 3,360.0 | 1,180.0 | 2,835.0 | 2,835.0 |
| | 3 | 2,626.0 | 1,180.0 | 2,835.0 | 2,626.0 | 3,300.0 | 1,195.0 | 3,690.0 | 3,300.0 |
| | Total | 8,612.0 | 3,540.0 | 8,505.0 | 8,087.0 | 9,960.0 | 3,570.0 | 10,215.0 | 9,435.0 |
| Total | | | | 26,087 | Total | | | | 29,824.5 |

- Deleted: 5,528.0
- Deleted: 1,348.0
- Deleted: 5,296.5
- Deleted: 5,296.5
- Deleted: 4,500.0
- Deleted: 1,467.0
- Deleted: 5,400.0
- Deleted: 4,500.0



A.5 Transmission

Project power connects to AEP's 69 kV distribution system at the single generator step-up transformer (GSU) located within the Byllesby switchyard (also known as the Byllesby 69 kV substation). The GSU is connected to the single 13.2 kV bus located within the Byllesby control house. Generator leads for each of the four Byllesby units are connected to this 13.2 kV bus. Generator leads for the three Buck units are connected to a common 13.2 kV bus within the Buck powerhouse, which is in turn connected to the two approximately 2-mile-long overhead 13.2 kV lines (Byllesby Buck #1 and Byllesby Buck #2) that cross the New River near the Buck spillway and extend to the Byllesby control house, where they connect to the 13.2 kV bus within. The GSU steps up the 13.2 kV generator voltage to 69 kV to match the voltage on the electrical distribution system.

Since constructed in 1911-1912, the Byllesby and Buck developments have been connected to a single transformer station located at the large "control house" building near the Byllesby powerhouse. The control house is located southwest of the Byllesby auxiliary spillway and several hundred feet back from the river. It is a two-level, rectangular, steel-framed, brick-walled building, surrounded by transformers and other appurtenant equipment. The building's interior contains offices, a maintenance area, and control rooms.

Primary transmission lines at the Project are limited to two approximately 2-mile long overhead 13.2-kV transmission lines (Byllesby Buck #1 and Byllesby Buck #2), which extend from the 13.2 kV bus within the Buck powerhouse to the 13.2 kV bus within the Byllesby control house.

Primary transmission lines at the Project are limited to the two 13.2-kV transmission lines (Byllesby Buck #1 and Byllesby Buck #2), which extend from the 13.2 kV bus within the Buck powerhouse to the 13.2 kV bus within the Byllesby control house.

Appurtenant mechanical, electrical, and transmission equipment required for efficient operation of the Byllesby powerhouse includes 13.2-kV generator leads to a 13.2-kV bus, the 13.2-kV bus, a 13.2-kV line from the bus to a 13.2/69 kV transformer, the 13.2/69 kV transformer, and the 69-kV connection from the transformer to the 69-kV transformer bus. Appurtenant mechanical and electrical equipment required for efficient operation of the Buck powerhouse includes 13.2-kV generator leads to a 13.2-kV bus, the common 13.2-kV bus, and 13.2-kV lines from the bus to the 13.2-kV Byllesby/Ivanhoe lines.



Specifications of additional mechanical and electrical equipment appurtenant to the Byllesby/Buck Hydroelectric Project are included in Table A.5-1 and Table A.5-2. The Project's single-line electrical diagram is included in Volume V of this draft license application (filed as CEII).

Table A.5-1. Appurtenant Mechanical, Electrical, and Transmission Equipment – Byllesby Development

| Equipment | Manufacturer | Description |
|------------------------------|--|--|
| 1) Exciters | Allis-Chalmers Mfg. Co. | 4-Type G Statex, Solid State, 75, kW, 250 V DC, 300 AMP |
| 2) Automatic Circuit Breaker | General Electric Company | Type C, Form K. 2,000 amps, 250 V |
| 3) Powerhouse Gantry Crane | Alliance | 57/5 Ton capacity |
| 4) Actuators | Woodward Governor Co. | Type A |
| 5) Trash Rakes | Northfork Electric | Dragrake operated by system of motorized cable hoists that move a raking beam in a cyclical motion |
| 6) Motor Hoist & Controls | Harnischfeger Corporation | Gear and screw lift shaft assembly |
| 7) | and other mechanical and electrical equipment required for efficient operation of the Project, including the following transmission equipment: | |
| a) | The 13.2 kV generator leads to the 13.2 kV bus; | |
| b) | The 13.2 kV bus (located within the Byllesby control house); | |
| c) | The 13.2 kV line from the bus to the 13.2/69 kV transformer; | |
| d) | The 13.2/69 kV transformer (located within the switchyard adjacent to the Byllesby control house); | |
| e) | The 69 kV connection from the transformer to the 69 kV transformer bus (located within the switchyard adjacent to the Byllesby control house). | |

Table A.5-2. Appurtenant Mechanical, Electrical, and Transmission Equipment – Buck Development

| Equipment | Manufacturer | Description |
|----------------------------|-----------------------|--|
| 1) Motor Generator Exciter | Westinghouse Electric | 1 – Type SK. DC Gen. 150 kW, 250 V, 600 amps, 1,180 rpm speed, shunt wound, style 6G6959 |
| 2) Powerhouse Gantry Crane | Alliance | 44/5 Ton Capacity |
| 3) Actuators | Woodward Governor Co. | Type A |
| 4) Trash Rake | Northfork Electric | Dragrake operated by system of motorized cable hoists that move a raking beam in a cyclical motion |



| | Equipment | Manufacturer | Description |
|----|--|---------------------|---------------------------------------|
| 5) | Motor Hoist & Controls | Harnischfeger Corp. | Gear and threaded lift shaft assembly |
| 6) | and other mechanical and electrical equipment required for efficient operation of the Project, including the following transmission equipment: | | |
| a) | The 13.2 kV generator leads to the 13.2 kV bus; | | |
| b) | The common 13.2 kV bus (located within the Buck powerhouse); | | |
| c) | The 13.2 kV line from the bus to the 13.2 kV Byllesby-Buck #1 and #2 transmission lines. | | |

A.6 Lands of the United States

The transmission corridor crosses 7.23 acres of federal lands (Jefferson National Forest). Appalachian understands these lands to be held in easement as the corridor pre-dates the Jefferson National Forest.

Most the land to the west of the Project is owned by the U.S. Forest Service and consists of the George Washington and Jefferson National Forest. The Mount Rogers National Recreation Area, a unit within the Jefferson National Forest and created in 1966, borders the Project to the west. These lands include approximately 100 acres of former Project lands that were transferred by Appalachian to the U.S. Forest Service in 1984, and subsequently removed from the Project Boundary, as authorized by FERC order dated December 18, 1984.

AMENDED FINAL LICENSE APPLICATION
BYLLESBY-BUCK HYDROELECTRIC PROJECT
(FERC No. 2514)

EXHIBIT B
PROJECT OPERATION AND RESOURCE UTILIZATION

This page intentionally left blank.



Exhibit B - Project Operation and Resource Utilization (18 CFR §4.51(c))

B.1 Description of Plant Operations

B.1.1 Drainage Basin Description

The Byllesby and Buck developments (collectively the Project) are situated in the upper New River Basin (Hydrologic Unit Code 0505001) which extends from the Bluestone Dam near Hinton, West Virginia, to the headwaters of the New River's north and south forks in northwestern North Carolina near Blowing Rock. The New River originates in the mountainous northwest corner of North Carolina at approximate EL. 3,700 ft and extends northward into Virginia and eventually empties into the Ohio River in West Virginia. The Byllesby Development is approximately 3 miles upstream of the Buck Development. The drainage area is 1,310 square miles for Byllesby and 1,320 square miles for Buck.

The New River originates in North Carolina at the confluence of the North Fork New River and the South Fork New River. It then flows northward for 320 miles through Virginia before entering West Virginia and flowing to the confluence of the Gauley River forming the Kanawha River, a tributary to the Ohio River. The New River flows through valleys ranging in width from 200 to 1,000 ft and has banks with precipitous bluffs and steep side slopes; steep gradients throughout much of the upper basin result in increased overland runoff and high flow velocities.

B.1.2 Project Operation

During the term of a new FERC license, Appalachian proposes to continue operating the Byllesby-Buck Hydroelectric Project in a run-of-river mode with a 1-ft normal reservoir operating band at each development. [Except for the bypass reach minimum flows proposed at each development,](#) there are no proposed changes to mode of operation.

Deleted: T

The Project operates in a run-of-river mode under all flow conditions. Because the Buck Development is approximately three miles downstream from the Byllesby Development, operations of the two developments are closely coordinated and operations at Buck are dependent on flows through Byllesby. Under normal operating conditions, Appalachian operates the Project to use available flows for powerhouse generation, maintaining the elevation of the Byllesby reservoir between EL. 2,078.2 ft and 2,079.2 ft and the Buck reservoir between EL. 2,002.4 ft and 2,003.4 ft.



Appalachian is also required to release a minimum flow of 360 cfs or inflow to the Project, whichever is less, downstream of the Project powerhouses.

Under normal operating conditions, the minimum flow requirements and normal headwater elevation is maintained by passing flow through the turbine generating units. The unit operations are monitored and controlled either locally from the plant's computer or remotely from AEP's COC in Columbus, Ohio. Tainter gate and Obermeyer gate operation at both Byllesby and Buck are also remotely controlled from AEP's COC. Operators are stationed at the control center twenty-four hours per day, seven days per week. Plant personnel are typically present at the Project during normal working hours Monday through Thursday to perform routine maintenance. The plant is staffed four days a week (typically Monday through Thursday), 10 hours a day during normal operating conditions.

As further described in the section below, when inflow to either development exceeds the discharge capacity of the powerhouse (5,511 cfs for Byllesby and 3,570 cfs for Buck, [following completion of upgrades proposed in this amended FLA](#)), the Obermeyer gates [and/or Tainter gates](#) are opened to pass the excess flow. Gate openings are planned and based on monitoring of the U.S. Geological Survey (USGS) gage 0316400, New River near at Galax, VA and Byllesby and Buck forebay elevations. Note AEP uses the Galax USGS gage to inform real-time operations, but USGS gage 03165500 New River at Ivanhoe provides a more complete history of flow conditions at the Project. If inflows exceed the capacity of the Obermeyer [and Tainter gates](#), the wooden flashboards are manually released. The wooden flashboards must then be subsequently re-installed during a period when the reservoir is drawn down to the spillway crest elevation.

Ramping rates are required under Article 406 of the [existing](#) license for the protection of fish resources downstream of the Buck spillway. The gradual reduction of flow allows fish to progressively leave the area, versus possible stranding at sudden flow discontinuation. Following periods of spill from the Buck spillway when a spillway gate has been opened 2 ft or more, Appalachian is required to discharge flows through a 2-ft gate opening for at least three hours. Appalachian is then required to reduce the opening to 1 ft for at least an additional 3 hours, after which Appalachian may close the gate. [The installation of new inflatable Obermeyer gates in Bays 11 – 14 and 25 and 26 will provide additional locations and methods for controlled spillway discharge and will have the potential to be operated to downramp spillway releases following periods of high spills. As a requirement of the new license, Appalachian proposes to develop and implement a modified ramping procedure for spillway gate \(i.e., Obermeyer gate and Tainter gate\) operations at the Buck Development to reduce the risk for stranding of fish in the bypass reach, as feasible, under a range of typical operating and inflow scenarios.](#)

Deleted: ,868

Deleted: 40

Deleted: Tainter gates and/or

Deleted: Tainter and



The frequency of spills to the bypass reaches during the period of record (POR), as well as dry and wet years, is presented in Table B.1-1. The values in the table below indicate the percentage of time in a given period where Project flows exceeded the hydraulic capacity of the powerhouse, which is the same as the percentage of time where there would have been spills to the bypass reach.

Table B.1-1. Exceedance Probability of Discharge to the Bypass Reaches at Byllesby and Buck Dams

| | Buck (3,540 cfs) | | | Byllesby (5,868 cfs) | | |
|---------------|------------------|-------|-------|----------------------|-------|-------|
| | 1996-2020 | 2008 | 2020 | 1996-2020 | 2008 | 2020 |
| Annual | 15.5% | 6.0% | 39.6% | 10.8% | 3.8% | 28.4% |
| Jan | 20.5% | 0.0% | 25.8% | 14.7% | 0.0% | 19.4% |
| Feb | 22.0% | 0.0% | 65.5% | 15.8% | 0.0% | 44.8% |
| Mar | 25.3% | 22.6% | 29.0% | 16.4% | 12.9% | 19.4% |
| Apr | 27.1% | 3.3% | 63.3% | 18.1% | 0.0% | 36.7% |
| May | 21.7% | 0.0% | 74.2% | 14.7% | 0.0% | 64.5% |
| Jun | 14.1% | 0.0% | 73.3% | 10.0% | 0.0% | 50.0% |
| Jul | 5.9% | 0.0% | 0.0% | 5.3% | 0.0% | 0.0% |
| Aug | 8.0% | 32.3% | 22.6% | 5.8% | 29.0% | 19.4% |
| Sep | 6.8% | 6.7% | 26.7% | 5.3% | 0.0% | 20.0% |
| Oct | 7.7% | 0.0% | 29.0% | 5.4% | 0.0% | 22.6% |
| Nov | 10.9% | 0.0% | 40.0% | 7.6% | 0.0% | 30.0% |
| Dec | 16.3% | 6.5% | 29.0% | 11.0% | 3.2% | 16.1% |

Note: 2008 was the driest average year of the 25-year record. 2020 was the wettest average year of the 25-year record. Data based on operational model and prorated hydrology data from USGS 03165500.

B.1.3 Flood Operations

B.1.3.1 Byllesby

When flows exceed the hydraulic capacity of the units during normal high-water events, or an outage or load rejection at the powerhouse forces a spillway discharge to maintain run-of-river operations, a combination of spillway gates are operated in accordance with Appalachian's standard operating procedure. As presently operated, and because of the time needed for gate openings to respond to operations actions or commands, Tainter Gate No. 6 is operated first to provide water control. After Tainter Gate No. 6 is fully open, Appalachians begins lowering Obermeyer gate No. 14 (or the farthest available Obermeyer from the powerhouse). More than one Obermeyer gate may be operated at one time. Tainter Gate No. 5 may then be opened to its full position, after which Appalachian typically lowers two Obermeyer gates. Tainter Gate No. 4 is then opened, after which

Deleted: (approximately 5,868 cfs)



[the remaining \(last\) Obermeyer gate is lowered. After all five Obermeyer gates are lowered, Appalachian continues with opening Tainter Gate Nos. 3, 2 then 1. To help keep debris away from the powerhouse intake screens when closing gates, Appalachian begins with the Tainter gates closest to the powerhouse and ends with the Tainter and Obermeyer gates farthest from the powerhouse.](#) The Tainter gates and Obermeyer gates are automated and can be remotely operated from the COC or manually on-site. The sluice gate is operated locally as needed to pass debris. The Obermeyer gates can also be used to sluice debris, as needed.

The plant is staffed 24 hours per day, 7 days per week during unusual (i.e., flood) conditions when all the gates are in full-open position.

In advance of a forecast of two or more inches of rain, AEP may determine that a reservoir drawdown below EL. 2,078.2 ft is needed. Mutual agreement is also required for drawdown below EL. 2,078.2 ft.

During flood-stage flows, all generating units at the powerhouse may be shut down due to the loss of operating head. As the reservoir continues to rise, and with all gates in the full-open position, the main dam flashboards are manually released as required to maintain the reservoir at or below EL. 2,081.5 ft. Flashboards are manually tripped at approximately 43,102 cfs. The Bylesby auxiliary spillway is operated after all Tainter and Obermeyer gates have been opened and all wooden flashboard sections have been released, typically at flows in excess of 46,690 cfs. Each flashboard stanchion is released by striking a release pin with a hand-held steel bar, shearing a nail through the pin, allowing the stanchion to drop. The release is accessed via a sleeve through the spillway bridge deck. The flashboard release sequence varies with flashboard sections with old or deteriorated timber members being released first. The flashboards are released only after all six Tainter gates and five Obermeyer gates are fully opened and the reservoir level continues to rise. The Water Filtration Plants at Ivanhoe and Allisonia are notified before releasing flashboards. Prior to releasing the auxiliary spillway flashboards, the Emergency Action Plan (EAP) for the Project is activated. [The installation of new inflatable Obermeyer gates in auxiliary Bays E and F will provide additional locations and methods for controlled spillway discharge. Appalachian expects to revise its internal flood operation procedures to address operation of the auxiliary spillway Obermeyer gates in association with final design and plan and specification approvals that will be required from the FERC Division of Dam Safety and Inspections – Regional Office prior to new gate installation during the new license term.](#)

Deleted: the Tainter gates are opened in sequence from right to left towards the powerhouse. Tainter Gate No. 6 is opened first using a dedicated electric hoist and primary power provided through the powerhouse. When Tainter Gate No. 6 reaches the full-open position, the Obermeyer gates are opened. The Obermeyer gates are opened sequentially from right to left beginning with Bay No. 14, furthest from the powerhouse. (As flows recede, the gates are closed in reverse order of opening.) Tainter Gate No. 5 is used to manage river flows while the Obermeyer gates are being opened. The Tainter gates and Obermeyer gates

During extreme flood conditions, once all the flashboards are released, the powerhouse unit head gates are closed, the powerhouse is de-energized and abandoned in preparation of dam overtopping. The powerhouse bulkhead door is closed to minimize flooding of the powerhouse.

The non-overflow (angled bulkhead) section begins to overtop at reservoir EL. 2,085.0 ft rendering the powerhouse and main spillway inaccessible. The spillway walkway and left abutment area are overtopped at reservoir EL. 2,087.5 ft, and flows proceed downstream to the Buck Development. The powerhouse generator floor at EL. 2,048.0 ft would be flooded by high tailwater when flows reached 192,000 cfs, based on tailwater rating curves. [The spillway capacity curve is shown on Figure B.1-1.](#)




Figure B.1-1. Byllesby Spillway Capacity Curve

B.1.3.2 Buck

During high flows that exceed the hydraulic capacity of the generating units, [or an outage or load rejection at the powerhouse forces a spillway discharge to maintain run-of-river operations, a combination of spillway gates are operated in accordance with a standard operating procedure](#)

Deleted: (approximately 3,540 cfs)



maintained by Appalachian. As presently operated, the Tainter gates are opened sequentially following sequence: 1 through 6 using a dedicated electric hoist and primary power provided through the powerhouse. The four Obermeyer gates are then operated sequentially 7 through 10 to maintain the reservoir at EL. 2,003.4 ft. As flows recede, the gates are closed in reverse order of opening. During the closing process for the last Tainter gate, the ramping procedure is implemented. The plant is staffed 24 hours per day, 7 days per week during unusual (i.e., flood) conditions when all the gates are in full-open position. The Tainter gates and Obermeyer gates are automated and can be remotely operated from the Columbus Operations Center (COC) or manually on-site. The Obermeyer gates can be used to sluice debris, as needed. The installation of new inflatable Obermeyer gates in Bays 11 – 14 and 25 and 26 will provide additional locations and methods for controlled spillway discharge, Appalachian expects to revise its internal flood operation procedures to address operation of the additional Obermeyer gates in association with final design and plan and specification approvals that will be required from the FERC Division of Dam Safety and Inspections – Regional Office prior to new gate installation in the new license term.

The plant is staffed 24 hours per day, 7 days per week during unusual (i.e., flood) conditions when all the gates are in full-open position.

In advance of a forecast of two or more inches of rain, AEP may determine that a reservoir drawdown below EL. 2,002.4 ft is needed. Agency approval is also required for drawdown below elevation 2,002.4 ft.

As the reservoir continues to rise, and with all gates in the full-open position, the flashboards are manually released as required to maintain the reservoir at or below EL. 2,005.5 ft. Flashboards are manually tripped at approximately 34,872 cfs. Each flashboard stanchion is released by striking a release pin with a hand-held steel bar, shearing a nail through the pin, allowing the stanchion to drop. The release is accessed via a sleeve through the spillway bridge deck. The flashboard release sequence varies with flashboard sections with old or deteriorated timber members being released first. The flashboards are released only after all six Tainter gates and four Obermeyer gates are fully opened, and the reservoir level continues to rise. The Water Filtration Plants at Ivanhoe and Allisonia are notified before releasing flashboards. The plant is staffed 24 hours per day, 7 days per week during unusual (i.e., flood) conditions when all the gates are in the full-open position.

During extreme floods, once all the flashboards are released, the powerhouse unit head gates are closed, the powerhouse is de-energized, bulkhead doors closed, and all staff would move upland in preparation of dam overtopping. The powerhouse bulkhead door is closed to minimize flooding of

the powerhouse. Prior to leaving the powerhouse, downstream communication is given in accordance with the EAP for the Project.

The main dam non-overflow sections and the spillway abutment at Mountain Island and wingwall sections begin to overtop at reservoir EL. 2,007.0 ft rendering the powerhouse, non-overflow sections and spillway bridge inaccessible. The spillway deck and left abutment are overtopped at reservoir EL. 2,010.0 ft. The powerhouse generator floor at EL. 1986.5 ft would be flooded by high tailwater when flows reached 175,000 cfs, based on tailwater rating curves. [The spillway capacity curve is shown on Figure B.1-2.](#)




Figure B.1-2. Buck Spillway Capacity Curve

B.1.4 Plant Factor

The annual plant factor is the ratio of estimated average annual generation from the plant (in megawatt hours per year [MWh/yr]) to the energy that the plant might produce if it operated at full capacity for one year. Based on historical generation results, the plant factors at Bylesby and Buck are 34.2 percent and 55.3 percent, respectively. Following completion of the unit upgrades proposed



by Appalachian, the plant factors are estimated to be 38.65 percent for Byllesby and 52.93 percent for Buck.

B.2 Estimated Energy Production and Dependable Capacity of the Project

B.2.1 Generation

Average annual historical generation at Byllesby and Buck over the past 50 years (approximately) is 53,913 MWh and 39,197 MWh, respectively. With the turbine-generator upgrades proposed by Appalachian for the new license term (Byllesby Units 1, 3 and 4 and Buck Units 1 and 3), average annual generation at the Byllesby and Buck developments is expected to increase to 70,600 and 48,220 MWh, respectively. Without the unit replacements, generation production and plant factors will degrade, and the probability of equipment failure will increase.

Deleted: Units 1, 2,

The Project operates in a run-of-river mode, and inflows to the Project are controlled by upstream flows. The Project experiences significant seasonal and annual variations in generation due to its run-of-river operation and seasonal precipitation events. Table B.2-1 provides a summary of monthly and annual generation in gross MWh for the past 5 years (2016 to 2020) for Byllesby and Table B.2-2 provides the same information for the Buck. This data also reflects the effects of plant and unit outages. Table B.2-3 provides a summary of monthly and annual average flows through the Byllesby-Buck Project (based on Byllesby outflows) in cfs for this same period from the USGS 03165500 New River at Ivanhoe, VA stream gage and prorating by drainage area.

Table B.2-1. Byllesby Monthly and Annual Generation (MWh) (2016-2020)

| Period | 2016 | 2017 | 2018 | 2019 | 2020 | Monthly Average |
|-----------|-------|-------|-------|-------|-------|-----------------|
| January | 6,757 | 4,318 | 2,902 | 6,496 | 5,526 | 5,200 |
| February | 3,976 | 2,369 | 6,383 | 5,198 | 4,476 | 4,480 |
| March | 7,270 | 3,183 | 3,692 | 6,752 | 6,775 | 5,534 |
| April | 4,324 | 5,561 | 4,850 | 8,098 | 5,304 | 5,627 |
| May | 5,649 | 8,778 | 6,103 | 7,164 | 5,096 | 6,558 |
| June | 3,215 | 5,275 | 5,299 | 7,372 | 5,292 | 5,291 |
| July | 1,822 | 2,941 | 2,783 | 5,834 | 4,887 | 3,654 |
| August | 2,662 | 2,771 | 3,840 | 4,049 | 5,083 | 3,681 |
| September | 1,129 | 2,731 | 2,247 | 2,113 | 4,492 | 2,542 |



| Period | 2016 | 2017 | 2018 | 2019 | 2020 | Monthly Average |
|--------------|---------------|---------------|---------------|---------------|---------------|-----------------|
| October | 1,400 | 3,919 | 4,188 | 3,778 | 4,163 | 3,489 |
| November | 1,046 | 3,882 | 5,754 | 4,327 | 2,565 | 3,515 |
| December | 2,849 | 2,609 | 5,373 | 5,251 | 2,712 | 3,759 |
| Total | 42,099 | 48,337 | 53,416 | 66,430 | 56,370 | 53,330 |

Table B.2-2. Buck Monthly and Annual Generation (MWh) (2016-2020)

| Period | 2016 | 2017 | 2018 | 2019 | 2020 | Monthly Average |
|--------------|---------------|---------------|---------------|---------------|---------------|-----------------|
| January | 5,366 | 3,597 | 2,255 | 1,482 | 5,391 | 3,618 |
| February | 4,563 | 1,883 | 3,584 | 1,362 | 5,784 | 3,435 |
| March | 5,941 | 2,298 | 1,595 | 3,759 | 5,449 | 3,808 |
| April | 3,937 | 4,668 | 3,773 | 4,057 | 4,847 | 4,256 |
| May | 4,394 | 6,445 | 4,962 | 3,887 | 5,006 | 4,939 |
| June | 2,986 | 4,138 | 3,532 | 3,992 | 3,048 | 3,539 |
| July | 2,113 | 2,203 | 1,852 | 3,341 | 3,064 | 2,515 |
| August | 2,609 | 2,191 | 3,896 | 2,105 | 4,503 | 3,061 |
| September | 583 | 2,028 | 3,660 | 1,119 | 3,875 | 2,253 |
| October | 1,170 | 3,062 | 2,438 | 2,152 | 3,872 | 2,539 |
| November | 1,056 | 2,588 | 3,444 | 1,981 | 4,366 | 2,687 |
| December | 2,261 | 1,629 | 2,385 | 2,851 | 5,072 | 2,839 |
| Total | 36,980 | 36,729 | 37,376 | 32,088 | 54,277 | 39,490 |

Table B.2-3. Monthly and Annual Average Project Outflows (cfs) (2016-2020)

| Period | 2016 | 2017 | 2018 | 2019 | 2020 | Monthly Average |
|----------|-------|-------|-------|-------|-------|-----------------|
| January | 3,106 | 2,162 | 1,986 | 5,129 | 3,477 | 3,172 |
| February | 5,450 | 1,229 | 3,207 | 6,559 | 5,579 | 4,405 |
| March | 2,943 | 1,312 | 2,727 | 3,929 | 3,586 | 2,900 |
| April | 1,974 | 4,114 | 4,802 | 4,816 | 4,956 | 4,132 |
| May | 2,359 | 5,315 | 5,148 | 3,006 | 8,714 | 4,908 |
| June | 1,826 | 2,287 | 2,932 | 4,599 | 4,130 | 3,155 |



| Period | 2016 | 2017 | 2018 | 2019 | 2020 | Monthly Average |
|----------------|--------------|--------------|--------------|--------------|--------------|-----------------|
| July | 1,146 | 1,304 | 1,602 | 2,402 | 2,364 | 1,764 |
| August | 1,438 | 1,160 | 2,342 | 1,619 | 3,472 | 2,006 |
| September | 773 | 1,182 | 4,783 | 970 | 3,068 | 2,155 |
| October | 945 | 2,456 | 5,337 | 1,701 | 3,648 | 2,817 |
| November | 751 | 1,638 | 3,807 | 2,052 | 4,806 | 2,611 |
| December | 1,044 | 1,145 | 7,017 | 2,826 | 3,378 | 3,082 |
| Average | 1,980 | 2,109 | 3,807 | 3,301 | 4,265 | 3,092 |

B.2.2 Dependable Generating Capacity

The estimated winter season dependable capacity for the Bylesby Development is 8 MW, while the estimated summer season dependable capacity is 5 MW. The estimated winter season dependable capacity for the Buck Development is 5 MW, while the estimated summer season dependable capacity is 3 MW. These estimates are based on the monthly project flow duration curves for the months of January (winter season) and August (summer season) and manufacturer’s data relative to equipment performance. Flow duration curves for January and August were chosen because peak demands for energy on the AEP system typically occur during these months.

B.2.3 Flows

Monthly flow data from the USGS 03165500 New River at Ivanhoe, VA flow gaging station is provided in Table B.2-4. This gage is located approximately 2.8 miles downstream of the Buck Development and reports daily average flow data starting in October 1929 through present, with a data gap from September 1978 to January 1996, providing a discontinuous 74-year POR. Monthly mean flow data, along with the 25th and 75th percentile flow data¹⁴ is provided from January 1996 through December 2020 (a 25-year POR¹⁵) to put recent historic river flows in perspective with

¹⁴ A percentile is a value on a scale of one hundred that indicates the percent of a distribution that is equal to or below it. A flow percentile greater than 75 is considered to be wetter than normal; a flow percentile between 25 and 75 is considered normal; and a flow percentile less than 25 is considered to be drier than normal.

¹⁵ The January 1996 – December 2020 POR is reflective of current land use and water use practices and uses more modern data collection and recording methods compared to the 1929 – 1978 POR. The more recent POR also contains a number of dry and wet periods that are sufficient for purposes of evaluating flow regimes relevant to the bypass reach flow and aquatic habitat study goals and objectives.



Byllesby and Buck maximum hydraulic capacities and current minimum downstream flow release requirements. For example, mean monthly flows recorded at the USGS 03165500 New River at Ivanhoe, VA gage are less than the hydraulic capacities of both the Byllesby and Buck developments. And while the monthly 75th percentile flows are less than the Byllesby powerhouse capacity, they exceed the smaller Buck powerhouse capacity. As a result, flow releases into the Buck bypass reach are more common than into the Byllesby bypass reach.

Table B.2-4 New River Flow Data (USGS Ivanhoe Gage), 1996 through 2020

| Month | Flow (cfs) | | | |
|-----------|------------|---------|--------|---------|
| | Average | Minimum | Median | Maximum |
| January | 2,553 | 393 | 2,090 | 32,701 |
| February | 2,869 | 582 | 2,350 | 26,588 |
| March | 2,833 | 762 | 2,600 | 16,205 |
| April | 3,068 | 1,067 | 2,590 | 23,386 |
| May | 2,849 | 804 | 2,270 | 40,173 |
| June | 2,120 | 448 | 1,790 | 20,475 |
| July | 1,681 | 365 | 1,290 | 21,833 |
| August | 1,453 | 176 | 1,100 | 22,707 |
| September | 1,564 | 244 | 984 | 29,693 |
| October | 1,596 | 263 | 1,140 | 29,111 |
| November | 1,892 | 440 | 1,300 | 27,753 |
| December | 2,360 | 551 | 1,990 | 19,310 |
| Annual | 2,236 | 921 | 1,800 | 25,828 |

An annual as well as monthly flow duration curves for flows through the Project are included in Section B.5. The flow duration curves are based on flow data from 1996 to 2020 at the USGS Ivanhoe gage, adjusted for drainage area as described above. Additionally, Appendix A of [Exhibit B in the FLA \(filed with the FLA¹⁶\)](#) includes supplemental flow duration figures with a truncated y-axis so magnitude, seasonality, and duration can be assessed.

Due to the small surface area of the impoundment, evaporation is not considered to be a significant factor. Leakage at the dam is also not a significant contributor to flows in the bypass reach.

B.2.4 Reservoir Storage Capacity

The gross storage capacity for the Byllesby impoundment is approximately 2,000 acre-ft with a total area of 239 acres. The gross storage capacity for Buck is approximately 661 acre-ft with a total area

¹⁶ <https://elibrary.ferc.gov/eLibrary/search: Docket Number P-2514, Accession Number 20220228-5319>



of 66 acres. Since each development is operated in a run-of-river mode, net storage capacity is not applicable. Storage-volume (storage capacity) curves for each development are included in Exhibit A, Figure B.2-1 and Figure B.2-2.




Figure B.2-1. Byllesby Development Reservoir Storage Capacity Curve




Figure B.2-2. Buck Development Reservoir Storage Capacity Curve

B.2.5 Hydraulic Capacity

B.2.5.1 Bylesby

The estimated combined maximum hydraulic capacity for all four existing turbine units installed at the Bylesby Development is 5,868 cfs. This estimate is based on manufacturer's turbine discharge information for all four units operating at full wicket gate opening and at a 56-ft head.

With the turbine-generator upgrades proposed by Appalachian for the new license term (Units 1, 3 and 4), the estimated combined maximum hydraulic capacity for all four turbine units is 5,511 cfs at full wicket gate opening and at a 54-ft head.

Deleted: Units 1, 2,



B.2.5.2 Buck

The estimated combined maximum hydraulic capacity for all three existing turbine units installed at the Buck Development is 3,540 cfs. This estimate is based on manufacturer's turbine discharge information for all three units operating at full wicket gate opening and at a 40-ft head.

With the turbine-generator upgrades proposed by Appalachian for the new license term (Units 1 and 3) the estimated combined maximum hydraulic capacity for all three turbine units is 3,570 cfs at full wicket gate opening and at a 42.4-ft head.

B.2.6 Tailwater Rating Curve

B.2.6.1 Byllesby

A tailwater rating curve for flows through the existing Byllesby generating units range is shown on Figure B.2-3. This rating curve was developed for the previous license application by curve fitting randomly selected discharges and elevations recorded from August 1988 through May 1990. A U.S. Army Corps of Engineers (USACE) HEC-II computer model of the tailwater area was also generated to estimate tailwater elevations for flows in excess of those recorded. The curve generated by the [HEC-II model](#) was verified by the actual data for flows ranging from 0 cfs through 6,000 cfs, and an extended tailwater rating curve for flows up to approximately 600,000 cfs is shown on Figure B.2-4.

Deleted: ing

Deleted: R




Figure B.2-3. Byllesby Development Tailwater Curve




Figure B.2-4. Byllesby Development Extended Tailwater Curve

B.2.6.2 Buck

A tailwater rating curve for flows through the existing Buck generating units is shown on Figure B.2-5. This rating curve was developed for the previous license application by curve fitting randomly selected discharges and elevations recorded from August 1988 through May 1990. A USACE HEC-II computer model of the tailwater area was also generated to estimate tailwater elevations for flows in excess of those recorded. The curve generated by the HEC-II model was verified by the actual data for flows ranging from 0 cfs through 4,000 cfs, and an extended tailwater rating curve for flows up to approximately 600,000 cfs is shown on Figure B.2-6.




Figure B.2-5. Buck Development Tailwater Curve




Figure B.2-6. Buck Development Extended Tailwater Curve

B.2.7 Head vs. Capability

The average head on the Project is based on the normal maximum forebay elevation and the normal tailwater elevation associated with the mean annual flow through the Project and is approximately 56.4 ft of net head for the existing Byllesby Development and 40 ft of net head for the existing Buck Development.

Minimum plant power output occurs when one unit operates at minimum discharge and maximum head conditions. Maximum plant power output occurs when both powerhouses are operating near full power output at approximately normal head conditions. The powerplant capability of the Byllesby and Buck developments from minimum output to maximum output is provided below.

Deleted: units

B.2.7.1 Bylesby

Estimates of plant capability for the existing units were developed from manufacturer's unit performance data for various discharges and associated head conditions. The Bylesby head versus powerplant capability at various operating head conditions is shown in Figure B.2-7. For this figure, a minimum headwater elevation of 2079.2 ft was assumed. By referencing the tailwater rating curve for the Bylesby Development, head conditions for turbine discharges associated with cumulative plant loadings were developed.




Figure B.2-7. Bylesby Development Head vs. Power Plant Capability

B.2.7.2 Buck

Estimates of plant capability for the existing units were developed from manufacturer's unit performance data for various discharges and associated head conditions. The Buck head versus powerplant capability at various operating head conditions is shown in Figure B.2-8. For this figure, a minimum headwater elevation of 2003.4 ft was assumed. By referencing the tailwater rating curve for the Buck Development, head conditions for turbine discharges associated with cumulative plant loadings were developed.




Figure B.2-8. Byllesby Development Head vs. Power Plant Capability

B.3 Power Utilization

Currently, Appalachian serves over 1 million customers, including both retail and wholesale customers, located in the states of Virginia, West Virginia, and Tennessee. Appalachian meets its customers' future capacity and energy requirements through operation of its fleet of generation resources and portfolio of power purchase agreements.

B.4 Future Development

As described in Exhibit A and in the sections above, Appalachian proposes to upgrade six of the seven existing turbine-generator units at the Project in the new license term. Following completion of the upgrades, the authorized installed capacities for the Byllesby and Buck developments will be 20.3895 MW and 9.435 MW, respectively, with maximum hydraulic capacities of 5,511 cfs and 3,570 cfs, respectively. The upgrades are necessary to support plant modernization and life extension.



Appalachian Power Company has no current plans for future development of any other existing or proposed water power project on the New River.

B.5 Flow Figures

The following figures include [existing](#) unit discharge flows as well as annual and monthly duration flow curves for each development. Additional annual and monthly flows for each development [were](#) provided in Appendix A of [Exhibit B in the FLA](#)¹⁷.

Deleted: are

Deleted: this

Deleted: exhibit

¹⁷ <https://elibrary.ferc.gov/eLibrary/search: Docket Number P-2514, Accession Number 20220228-5319>




Figure B.5-1. Byllesby Development: Flow Through One Unit (Existing Units)




Figure B.5-2. Buck Development: Flow Through One Unit (Existing Units)




Figure B.5-3. Byllesby Development: Flow Through One Tainter Gate




Figure B.5-4. Buck Development: Flow Through One Tainter Gate




Figure B.5-5. Byllesby Development: Flow Through One Obermeyer Gate




Figure B.5-6. Buck Development: Flow Through One Obermeyer Gate




Figure B.5-7. Byllesby Development: Flow Over Vertical Drop (Sluice) Gate




Figure B.5-8. Buck Development: Flow Through Vertical Lift (Sluice) Gate




Figure B.5-9. Byllesby Development Daily Average Inflow




Figure B.5-10. Byllesby Development Monthly Average Inflow




Figure B.5-11. Buck Development Daily Average Inflow




Figure B.5-12. Buck Development Daily Average Inflow




Figure B.5-13. Byllesby Development Monthly Flow Duration Curves




Figure B.5-14. Byllesby Annual Rating Curve




Figure B.5-15. Bylesby Development January Flow Duration Curve




Figure B.5-16. Bylesby Development February Flow Duration Curve




Figure B.5-17. Bylesby Development March Flow Duration Curve




Figure B.5-18. Bylesby Development April Flow Duration Curve




Figure B.5-19. Bylesby Development May Flow Duration Curve




Figure B.5-20. Bylesby Development June Flow Duration Curve




Figure B.5-21. Byllesby Development July Flow Duration Curve




Figure B.5-22. Byllesby Development August Flow Duration Curve




Figure B.5-23. Bylesby Development September Flow Duration Curve




Figure B.5-24. Bylesby Development October Flow Duration Curve




Figure B.5-25. Bylesby Development November Flow Duration Curve




Figure B.5-26. Bylesby Development December Flow Duration Curve




Figure B.5-27. Buck Development Monthly Flow Duration Curves




Figure B.5-28. Buck Development Annual Rating Curve




Figure B.5-29. Buck Development January Flow Duration Curve




Figure B.5-30. Buck Development February Flow Duration Curve




Figure B.5-31. Buck Development March Flow Duration Curve




Figure B.5-32. Buck Development April Flow Duration Curve




Figure B.5-33. Buck Development May Flow Duration Curve




Figure B.5-34. Buck Development June Flow Duration Curve




Figure B.5-35. Buck Development July Flow Duration Curve




Figure B.5-36. Buck Development August Flow Duration Curve




Figure B.5-37. Buck Development September Flow Duration Curve




Figure B.5-38. Buck Development October Flow Rating Curve




Figure B.5-39. Buck Development November Flow Duration Curve




Figure B.5-40. Buck Development December Flow Duration Curve

AMENDED FINAL LICENSE APPLICATION

BYLLESBY-BUCK HYDROELECTRIC PROJECT (FERC No. 2514)

EXHIBIT C

**CONSTRUCTION HISTORY AND PROPOSED CONSTRUCTION
SCHEDULE**

This page intentionally left blank.



Exhibit C - Construction History and Proposed Construction Schedule (18 CFR §4.51(d))

C.1 Construction of Existing Facilities

Because 18 CFR §4.51(d)(1) requires a construction history only for applications for an initial license, a construction history is not required for this relicensing application for the Project. However, to provide general and background information, a brief summary of the construction history of the Project is included below.

The construction and major events/alterations/repairs to each development are listed below.

C.1.1 Byllesby Development

The Byllesby Dam was constructed in 1912 to provide hydropower for the New River Power Company and Appalachian acquired the development in 1926. Original engineering was performed by Viele, Black and Buck, Consulting Engineers, New York, NY.

- In 1928, severe deterioration led to removal and replacement of defective concrete.
- The August 1940 Flood of Record caused substantial damage to the generating machinery when the powerhouse was flooded.
- To address the dam's stability and factors of safety under the Probable Maximum Flood loading conditions, post tensioned rock anchors were installed in September 1992 and April 1993 in all water-retaining structures.
- Concrete restoration was conducted during 1993 and 1994 to repair freeze-thaw damage and spalled areas. Other improvements included underpinning the toe of the main spillway and concrete (to address undercutting), and pressure grouting the powerhouse substructure to control leakage.
- In 1998, an Obermeyer (pneumatic) gate was installed in the main spillway. The gate replaced the flashboards in one spillway bay.
- In 2000, the main spillway and auxiliary spillway timber walkways were replaced with steel grating.
- In 2002, concrete restoration on the downstream face of angled bulkhead was performed.
- In 2003, spillway Gates No. 2 and 3 were repaired. The lower section of the skin plate and all the vertical rib supports were replaced and repainted. The bottom and side seals were also replaced.



- In 2004, spillway Gates No. 1, 4, 5, and 6 were replaced.
- In 2006, concrete restoration was performed on the upstream side of the spillway crest. The concrete slab on the west side of powerhouse at the generator floor level was replaced. The trash racks in front of all 4 units were replaced and the steel support members were repaired or replaced as required. Work began on replacing the Unit 4 headgate.
- In 2007, concrete restoration was performed on the downstream spillway surface at the main spillway flashboard section Bay 8. Concrete restoration was also performed on the main spillway right abutment wall. The Unit 4 headgate installation was completed, and work began on replacement of the Unit 3 headgate.
- In 2008, the Unit 3 headgate installation was completed as well as replacement of the Unit 1 and 2 headgates.
- On the night of January 17, 2010 large blocks of ice broke free upstream of Byllesby Dam and the force of the ice on spillway resulted in eight sets of flashboards failing. The flood wave mixed with ice sheets reached Buck Dam, approximately 3 miles downstream, in less than 30 minutes.
- In 2010, the six spillway Tainter gates were automated to be operated from the COC. In addition, repairs were made to the concrete caps over two post tensioned anchor heads.
- In 2012, new spillway gate operators were installed on all six spillway Tainter gates.
- In January 2013, the right spillway abutment and the non-overflow bulkhead section of the dam were overtopped during a flood event. Minor scour occurred on the downstream side of the angled bulkhead. The powerhouse was flooded with approximately 1 to 2 ft of water, which forced the generation units offline. In addition the flood event silted in the forebay in front of the intakes and damaged the intake structures.
- In 2014, the forebay was dredged and the intake structure and screens were repaired. Concrete restoration of the downstream face of spillway bay 15 was performed. All flashboards on the main spillway and auxiliary spillway were replaced and repairs were made to all four generating units.
- In 2015, spillway Tainter gate anchors were installed.
- In 2016, two new Obermeyer gates were installed to replace the stanchion flashboards in Bays 12 and 13.
- In 2018, two new Obermeyer gates were installed to replace the stanchion flashboards in Bays 10 and 11.



C.1.2 Buck Development

The Buck Dam was constructed in 1912 to provide hydropower for the New River Power Company and Appalachian acquired the development in 1926. Original engineering was performed by Viele, Black and Buck, Consulting Engineers, New York, NY.

- In 1928, expansive concrete due to the use of phyllite aggregates and high alkali cement resulted in significant damage in the powerhouse causing misalignment between the turbine and generator which broke the turbines' stay rings. The concrete floor supporting the generators and turbines was removed to a depth of 5 ft below the scroll case floor and was replaced with a new concrete floor. The damaged stay rings were also removed, repaired, and replaced.
- Within ten years, additional concrete repairs were made to the 1928 work due to deterioration. The exterior concrete surfaces on the powerhouse substructure, bulkhead sections of the dam, and spillway were removed to an average depth of 4 inches, with some areas requiring as much as 18 inches locally. Stage grouting was used to stop leakage through construction joints. The new concrete facing was divided into panels with v-joint separations to localize cracking and allow sealing of the joints; it was met with limited success.
- The August 1940 Flood of Record resulted in substantial damage to the generating machinery when the powerhouse was flooded.
- The spillway bridge and gate piers were replaced in 1988.
- To address potential stability concerns under the Probable Maximum Flood loading conditions, post tensioned rock anchors were installed between April and November of 1993 in all water-retaining structures.
- Concrete restoration was conducted during 1993 and 1994, consisting of epoxy grouting for leakage control through structures and filling the undercut area of the spillway toe with concrete.
- In 2001, the monitoring program for the piezometers in the spillway and main dam was discontinued based on recommendations made by the independent consultant for the Fifth Part 12 Safety Inspection.
- In 2002, concrete repairs to the deck on top of the north non-overflow bulkhead section were performed. The deck was chipped down 6 inches and repoured. The concrete caps over the post-tensioned anchors heads were also restored.
- In 2006, the I.P. Morris vertical Francis turbine runner for Unit 2 was replaced with a new vertical Francis turbine runner manufactured by American Hydro.

Deleted: 3



- In 2007, the concrete caps over six post-tensioned anchors in the main spillway were restored.
- On the night of January 17, 2010 ice jams on the New River resulted in overtopping of the non-overflow bulkheads at the Buck Development. Large blocks of ice broke free upstream of Byllesby Dam and the force of the ice on spillway resulted in eight sets of flashboards failing. The flood wave mixed with ice sheets reached Buck Dam in less than 30 minutes. The surge of water raised the pond level several feet until 3 sets of flashboard bays finally failed 1 hour and 45 minutes later, allowing the Buck pond to begin dropping.
- Minor overtopping of the abutments at the Buck Dam occurred during the peak of the event; however, there was no loss of integrity of the water impounding structures. The damage was limited to minor erosion around the toe of the left concrete bulkhead, bent handrails, and damaged log boom sections.
- Also in 2010, the six spillway Tainter gates were automated so they could be operated from the COC.
- In 2012 and 2013, repairs were made to the concrete caps over several post-tensioned anchors where the concrete was cracked or eroded. Concrete restoration was also performed on the two left spillway bay downstream surfaces.
- On January 31, 2013, heavy rains contributed to high river flows on the New River in Southwest Virginia resulting in overtopping of the Byllesby and Buck dams creating an emergency condition. At the spillway bridge, the right abutment was overtopped which washed out stone on the entrance road and eroded the fill material on the downstream shoreline where the water reentered the river. At the powerhouse, the right and left non-overflow bulkheads were overtopped. The loss of fill material was not a dam safety concern. The powerhouse was flooded by about six inches. The top of the head covers and guide bearings were flooded on all the units. All necessary repairs were made in 2013 and the forebay was returned to normal operating level in December 2013.
- In 2014, repairs were made to the intake structure. The horizontal support beams were replaced and the vertical support members were reinforced. The intake screens were also replaced.
- Repairs were made to the gate hoist anchorage in 2015.
- In 2017, two new Obermeyer gates were installed to replace the flashboards in Bays 7 and 8.
- In 2018-2019, two new Obermeyer gates were installed to replace the stanchion flashboards in Bays 9 and 10.



C.2 Construction of Proposed Facilities

During the new license term, Appalachian proposes to modernize the Byllesby and Buck developments to include replacement of Byllesby [Units 1, 3](#) and 4 and Buck Units 1 and 3. All but one (Buck Unit 2) of the seven turbine-generator units installed at the Project are the original major components of the Project as constructed in 1912. The existing vertical Francis units would be replaced by fixed blade Kaplan units. Unit upgrade activities would be confined to within the powerhouse, and there would be minimal changes to operating parameters for the Project.

Deleted: Units 1, 2,

Appalachian is presently planning [the following schedule for unit upgrades at the Project and notes the schedule is subject to change before or during implementation:](#)

Deleted: a

Deleted: three-phase unit replacement program for the

- [2024: Byllesby Unit 4](#)
- [2025: Buck Unit 1](#)
- [2026: Byllesby Unit 3](#)
- [2027: Byllesby Unit 1](#)
- [2028: Buck Unit 3](#)

[Existing Byllesby Unit 2 and Buck Unit 2 would remain in place and would be operated as last unit on and first unit off for each development.](#)

Deleted: . The first phase involves the replacement of Byllesby Unit 4 starting in 2024. The second phase involves the replacement of Byllesby Units 1 and 2 in 2025 and 2026; ...e

Deleted: e

Deleted: 3

[Appalachian proposes to commence the planned Obermeyer gate installations at the Project in 2024, starting with the Buck Development. Appalachian presently expects gate installations at Buck would be complete within 3 years of commencement, after which gate installations at the Byllesby Development would begin, with completion within 2 years of commencement. Appalachian plans to file a detailed schedule for the gate installations with the final design and plan and specifications with the FERC Division of Dam Safety and Inspections – Regional Office. FERC approval is required prior to new gate installation in the new license term.](#)

Deleted: The third phase involves the replacement of Buck Units 1 and 3 in 20257 and and 20278, respectively. Existing Buck Unit 2 would remain in place and would be operated as last unit on and first unit off.¶

This page intentionally left blank.

AMENDED FINAL LICENSE APPLICATION
BYLLESBY-BUCK HYDROELECTRIC PROJECT (FERC No. 2514)

EXHIBIT D
COSTS AND FINANCING



Exhibit D - Costs and Financing (18 CFR §4.51(e))

D.1 Original Cost of Project

Since the Project is applying for a new license for an existing project, as compared to an initial license, a tabulated statement providing the actual or approximate cost of Project construction is not applicable.

D.2 Project Takeover Cost Pursuant to Section 14 of the FPA

Under Section 14(a) of the Federal Power Act (FPA), the federal government may take over any project licensed by the Commission upon the expiration of the original license. The Commission may also issue a new license in accordance with Section 15(a) of the FPA. If such a takeover were to occur upon expiration of the current license, the Licensee would have to be reimbursed for the net investment, not to exceed fair value, of the property taken, plus severance damages. To date, no agency or interested party has recommended a federal takeover of the Project pursuant to Section 14 of the FPA.

D.2.1 Fair Market Value

Fair market value is not defined in the FPA or its implementing regulations. The fair value of the Project depends on prevailing power values and license conditions, both of which are currently subject to change. The best approximation of fair value is likely to be the cost to construct and operate a comparable power generating facility. Because of the high capital costs involved with constructing new facilities and the increase in fuel costs associated with operating such new facilities (assuming a fossil-fueled replacement), the fair value would be considerably higher than the net investment amount. If a takeover were to be proposed, the Licensee would calculate fair value based on then-current conditions.

For the purposes of this Exhibit, Appalachian is providing the current net book value for the Project in Table D.2-1.



Table D.2-1. Byllesby-Buck Project Net Book Value

| Utility Account | Through-Period | Book Cost | Allocated Reserve | Net Book Value |
|--|----------------|----------------------|----------------------|---------------------|
| 302 - Franchises and Consents | 12/2021 | \$ 400,843 | \$ 371,430 | \$ 29,413 |
| 331 - Structures and Improvements | 12/2021 | \$ 1,216,147 | \$ 1,017,947 | \$ 198,201 |
| 332 - Reservoirs, Dams & Waterway | 12/2021 | \$ 7,441,024 | \$ 5,321,204 | \$ 2,119,820 |
| 333 - Water Wheels, Turbines, Generators | 12/2021 | \$ 3,697,214 | \$ 2,977,955 | \$ 719,259 |
| 334 - Accessory Electric Equipment | 12/2021 | \$ 1,081,017 | \$ 1,010,704 | \$ 70,313 |
| 335 - Misc Power Plant Equipment | 12/2021 | \$ 1,037,294 | \$ 854,617 | \$ 182,677 |
| 337 - ARO Hydr_aulic Production | 12/2021 | \$ 72,046 | \$ 58,475 | \$ 13,571 |
| Total | 12/2021 | \$ 14,945,585 | \$ 11,612,332 | \$ 3,333,253 |

D.2.2 Net Investment

The total lifetime investment in the Project through December 31, 2021 was approximately \$14,945,585. The net investment in the Project (investment minus lifetime depreciation expense) through December 31, 2021 was approximately \$3,333,253. This value should not be interpreted as the fair market value of the Project.

D.2.3 Severance Damages

Severance damages are determined either by the cost of replacing (retiring) equipment that is “dependent for its usefulness upon the continuance of the License” (Section 14, FPA), or the cost of obtaining an amount of power equivalent to that generated by the Project from the least expensive alternative source, plus the capital cost of constructing any facilities that would be needed to transmit the power to the grid, minus the cost savings that would be realized by not operating the Project. These values would need to be calculated based on power values and license conditions at the time of Project takeover.

The following calculation of severance damages is based on the assumption that severance damages are to be measured by the cost to Appalachian of effectively replacing the utility service provided by the Project.

The calculation of severance damages assumes that takeover of the Project would occur upon expiration of the license in 2024. However, it must be realized that an alternative source of comparable energy could not be constructed by this date. Therefore, the calculation should include the very substantial cost to Appalachian for temporary replacement of capacity which, in general, would be assumed to be at the then-current market price. Due to the highly conjectural nature of these calculations, these costs have not been included in the calculation of severance damages included herein.



The present worth of the annual cost of owning the replacement capacity was determined on the basis of the cost of the most likely alternative source of capacity and energy capable of providing dependable capacity and net output equivalent to that expected to be supplied by the Project over a 50-year period. The calculation assumes that the alternative power supply would consist of fractional shares of combined cycle peaking gas plant (see additional information in Exhibit H, Section H.1), which would be placed in service in 2029. (For the years 2024 through 2029, replacement energy would be supplied by the AEP System's existing capacity and is not included in the calculation below.) Out of recognition of the greater availability of the hydroelectric plants as compared with gas-fired plants, the amount of thermal capacity considered to be equivalent to the Project's capacity was increased by 30%.

The estimate of severance damages is calculated as follows:

| | | |
|--------------------------------|---|---------------------|
| (1) | Cumulative present worth of the annual cost of owning the replacement capacity (costs begin in 2029) | \$24,000,000 |
| (2) | Cumulative present worth of annual costs of replacement energy | \$2,500,000 |
| (3) | Estimated net investment in the Project | - \$2,600,000 |
| (4) | Present value of annual costs of ownership (other than net investment costs) and operation of the Project | - \$3,562,500 |
| Total severance damages | | \$20,337,500 |

On the basis of the calculation above, the amount due to Appalachian in case of takeover as of 2024 for net investment not exceeding the fair value plus severance is estimated to be \$20,337,500.

Substantial additional detriments due to changes in operational flexibility, reserves, renewable generation goals and benefits, and other matters are not included in the above estimates. These estimates were developed by Appalachian within the limits of information available at the time the application was prepared and are being submitted without prejudice to Appalachian's right to reevaluate the entire question of the amount payable for takeover in light of information available at a later time.



D.3 Estimated Costs of New Development

D.3.1 Land and Water Rights

The Licensee currently holds all land and water rights necessary to construct, operate and maintain the Project, and is not proposing expansion of its land or water rights as a consequence of this license application.

D.3.2 Cost of New Facilities

Construction of new facilities during the new license term is not presently proposed by Appalachian. During the new license term, Appalachian does propose to modernize the Byllesby and Buck developments to include replacement of Byllesby ~~Units 1, 3 and 4~~ and Buck Units 1 and 3. Appalachian's preliminary cost estimate for these upgrades over the new license term is \$32,023,000.

Deleted: Units 1, 2,

[As described in Exhibits A and B, Appalachian proposes to replace a total of nine wooden flashboard sections at the Project with inflatable Obermeyer gates \(three at Byllesby and six at Buck\). Appalachian's preliminary cost estimate for gate installations over the new license term is \\$5,400,000.](#)

Costs for other new facilities proposed as PM&E measures for the new license term, are provided in Section D.4.1.5.

D.4 Estimated Average Annual Cost of Project

There is no fixed schedule for other elements of the Project's general life-extension program, rather a sequence of activities designed to be implemented when needed. Accordingly, there is not a fixed annual budget allocated for additional life-extension activities. These activities would be performed on an as-needed basis using existing planning procedures that provide short- and long-term windows to evaluate, schedule, and budget replacements and rehabilitation work in an orderly fashion.

D.4.1 Current Annual Costs

The average annual cost of the Project, including costs associated with existing and projected Project operations and maintenance, as well as local property and real estate taxes, but excluding income taxes, other taxes, depreciation, and costs of financing, for the period 2017-2021 was \$1,045,809.



D.4.1.1 Cost of Capital (Equity and Debt)

Average annual Project capital costs for the period 2017-2021 were \$808,100. Actual capital costs are based on a combination of funding mechanisms that include stock issues, debt issues, revolving credit lines, and cash from operations. For the period 2022-2026, the estimated average annual Project capital costs are \$6,680,813.

D.4.1.2 Local, State, and Federal Taxes

Average annual property taxes for the period 2017-2021 were \$83,921. Income taxes for the Project are incorporated into costs of the Licensee's consolidated business and are not separated out for the Project.

D.4.1.3 Depreciation and Amortization

As of December 31, 2021, the annualized composite rates of depreciation for the Project by plant account were as follows:

- 331 - Structures and improvements: 9.83%
- 332 – Reservoirs, dams and waterways: 12.90%
- 333 – Water wheels, turbines and generators: 11.69%
- 334 – Accessory electric equipment: 7.18%
- 335 – Miscellaneous power plant equipment 9.53%:

As of December 31, 2021, the total depreciation or amortization expense was \$1,692,326

D.4.1.4 Operation and Maintenance Expenses

The average annual O&M expense for the Project, including corporate support costs, but excluding property and real estate taxes, for the period 2017-2021 was \$978,154.

D.4.1.5 Estimated Capital and O&M Costs of Proposed PM&E Measures

Appalachian has proposed a number of measures for the PM&E of environmental resources associated with the Project. The proposed environmental enhancements will not require any new lands or water rights for which Appalachian does not already have ownership or rights. The estimated capital and annual costs of PM&E measures proposed by Appalachian at the Project are presented in Table D.4-1.



Table D.4-1. Preliminary Cost Estimate of Resource PM&E Measures Proposed by Appalachian at the Byllesby-Buck Project

| Item | Capital Cost (2022 Dollars) | Incremental Operations & Maintenance or Annual Cost (2022 Dollars) |
|--|--------------------------------|--|
| Develop an updated Operating Compliance Monitoring Plan for FERC approval and in consultation with USFWS, VDWR, and VDEQ, with provisions for monitoring compliance with the operational requirements of the new license: description of gages or recording devices used to monitor operation compliance; processes for reporting deviations during normal operations, during emergencies, and for planned variances for Project maintenance or other purposes; and an implementation schedule. | \$20,000 | \$10,000 |
| Continue funding of the USGS New River at Galax and Ivanhoe gages. | - | \$25,400 |
| Continue to provide a minimum flow of <u>approximately</u> 360 cfs, or inflow through the Project, whichever is less, to the New River downstream of each powerhouse. | - | - |
| Implement existing ramping rate for the Buck Development bypass reach with minor modification described within this amended FLA. After the commissioning of new Obermeyer gates in Buck spillway Bays 25 and 26, develop a modified ramping procedure for spillway gate operations at Buck in consultation with USFWS, VDWR, and VDEQ and filed with FERC for approval. | \$20,000 | - |
| At the Byllesby Development, provide a continuous bypass reach minimum flow of approximately 35 cfs from any one or combination of the Obermeyer gates installed on the main spillway. ¹⁸ | \$5,000 | \$41,800 ¹⁹ |
| At the Buck Development, for the protection of Walleye during spawning season, from February 15th – May 15th annually, provide a continuous bypass reach minimum flow at of approximately 100 cfs from Obermeyer gates in Bays 25 and/or 26. ¹⁸ | \$5,000 | \$10,900 ¹⁹ |
| Conduct Project maintenance and new license implementation activities, as applicable, in accordance the USFWS's prevailing eagle management guidance and regulations. | \$10,000 | \$5,000 |
| Implement measures for the protection of listed bat species that may occur at the Project over the new License term. | \$10,000 | \$50,000 |
| Finalize and implement Recreation Management Plan in consultation with Project stakeholders, including provisions for improvements to existing Project facilities (Byllesby Boat Launch, Byllesby Dam Fishing Access, Byllesby Canoe Portage (Take-Out), New River Canoe Launch (Put-In), and Buck Canoe Portage | \$511,500 | \$28,500 |

Deleted: Continue to operate the Project in a run-of-river mode. Develop an updated

Deleted: Implement proposed modified ramping rate for spillway gate operations at the Buck development.

Deleted: Develop and implement a Bypass Reach Aquatic Resources Protection Plan in consultation with USFWS and VDWR and for FERC approval. \$50,000

¹⁸ Does not include capital costs of new Obermeyer gate installation, which are provided in Section D.3.2 (\$5,400,000).

¹⁹ Approximate value of lost generation based on values provided in Sections D.4.2 and D.8.



| Item | Capital Cost (2022 Dollars) | Incremental Operations & Maintenance or Annual Cost (2022 Dollars) |
|--|--------------------------------|--|
| (Take-Out and Put-In) and construction of the Non-Project Loafer's Rest Area and Fishing Trail. ²⁰ | | |
| Finalize in consultation with consulting parties (Tribes, SHPO) the Historic Properties Management Plan. | \$5,000 | \$1,500 |
| Total | \$581,500 | \$123,100 |

Deleted: , and FERC

Deleted: draft

D.4.2 Annual Value of Project Power

Appalachian sells all of the electricity generated at the Project into PJM Interconnection²¹ (PJM). Based on average 2021 revenue for the Project of \$34.44/MWh and generation in 2021 of 73,233 MWh, in 2021 the value of Project power was \$2,522,242.

D.5 Sources and Extent of Financial and Annual Revenues

If determined to be needed, Appalachian's general plan for financing the environmental enhancements and life-extension cost of the Project initially will be to issue short-term debt (either bank line of credit or commercial paper) and to generate internal funding consisting of depreciation, retained earnings, and deferred federal income taxes. If short-term financing options become unattractive, Appalachian will issue permanent securities (i.e., long-term debt, preferred stock, and common stock) to replace short-term debt. This financing plan will adhere to Appalachian's overall corporate construction financing requirements.

D.6 Cost to Develop the License Application

The approximate cost to prepare the application for new license for the Project through February 28, 2023, is \$2.2 million.

²⁰ The estimated costs break-down (in 2022 dollars) for recreation facilities is as follows: Bylesby Boat Launch (Capital Cost=\$86,000, O&M=\$10,000); Bylesby Dam Fishing Access (Capital Cost=\$7,000, O&M=\$2,000); Bylesby Canoe Portage (Capital Cost=\$4,500, O&M=\$2,500); New River Canoe Launch (Capital Cost=\$3,500, O&M=\$2,500); Buck Canoe Portage (Capital Cost=\$55,000, O&M=\$1,500); Loafer's Rest (Capital Cost=\$355,000, O&M=\$10,000).

Formatted: Justified

Deleted: ;

²¹ The PJM Interconnection is a regional transmission organization that coordinates the movement of electricity in all or parts of 13 Mid-Atlantic and Midwestern states plus the District of Columbia.



D.7 On-Peak and Off-Peak Values of the Project

The Project operates as a run-of-river generating facility. As per 18 CFR Â§ 4.51(e)(8), this section is not applicable to hydroelectric projects operating in run-of-river mode.

D.8 Estimated Average Increase or Decrease in Generation

The unit upgrades proposed by Appalachian are expected to increase average annual generation by approximately 25,927 MWh.

In the new license term, Appalachian is proposing to provide a continuous bypass reach minimum flow of approximately 35 cfs at the Byllesby Development and a seasonal (February 15th – May 15th) bypass reach minimum flow of approximately 100 cfs at the Buck Development. These new bypass reach minimum flows will decrease annual generation. The Project will experience an estimated annual reduction of generation of approximately 1,529 MWh compared to continued operation as otherwise proposed in the Amended FLA (i.e., upgraded Project condition), a reduction of approximately 1.2 percent. Based on the annual value of power presented in Section D.4.2, this reduction in generation would decrease the annual value of power generated at the Project by an additional (approximately) \$52,700 (excluding any additional capital costs).

As discussed in Section E.15.3 of Exhibit E of the FLA, preliminary minimum bypass flow recommendations by USFWS (88 cfs at Byllesby and approximately 360 cfs at Buck) would result in an average annual reduction of generation (assuming the existing, not upgraded, equipment) of 11,506 MWh.

D.9 PURPA Benefits

Appalachian will not be seeking benefits under Section 210 of the Public Utility Regulatory Policies Act (PURPA) of 1978 for qualifying hydroelectric small power production facilities in §292.203 of this chapter.

Deleted: is not presently proposing any PM&E measures or operational modifications at the Project that would cause a ...

Deleted: in

Deleted: or decrease in the value of project power

Deleted: is



Appendix A

Appendix A – Byllesby-Buck
Supplemental Flow
Exceedance Plots (Exhibit B)
– [Previously Filed with FLA](#)

